

ALBERTA INFRASTRUCTURE
EMCS GUIDELINE FOR
LOGICAL POINT MNEMONICS

Roman G. Unyk, P.Eng.
Manager, EMCS
Phone: (780) 422-7469
E-mail: roman.unyk@gov.ab.ca
Alberta Infrastructure
Technical Resources and Standards Branch
Mechanical Engineering Section
March, 2002

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

TABLE OF CONTENTS

| | | |
|-----|---|----|
| 1.0 | Introduction | 3 |
| 2.0 | Physical Points – Specifics | 5 |
| 3.0 | Virtual Points – Specifics | 8 |
| 4.0 | Standard for Logical Point Mnemonics | 12 |
| | Physical Point Attributes | 14 |
| | Air Systems: | |
| | AH Air Handler – Packaged Controls | 14 |
| | AH Air Handler – Single Zone or Terminal Reheat ... | 15 |
| | DD Dual Duct Air System | 16 |
| | IS Induction System | 16 |
| | MU Make-up air Unit | 16 |
| | MZ Multizone Air System | 17 |
| | VV Variable Volume Air System | 18 |
| | Cooling Systems: | |
| | CT/DCCooling Tower/Dry Cooler System | 19 |
| | CW Cooling System: Chilled Water System | 20 |
| | Electrical Systems: | |
| | LS Lighting System | 21 |
| | PL Parking Lot | 21 |
| | PD Power Distribution | 21 |
| | Heating Systems: | |
| | BA Boiler <i>combustion</i> Air | 22 |
| | BS Boiler System | 23 |
| | HE Heat Exchanger | 24 |
| | HW Heating Water | 25 |
| | PR Perimeter Radiation | 26 |
| | RP Radiant Panel | 26 |
| | TR Terminal Reheat | 27 |
| | Other Systems: | |
| | CA Control Air | 27 |
| | DCW Domestic Cold Water | 28 |
| | DHW Domestic Hot Water | 28 |
| | FA Fire Alarm | 29 |
| | FP Fire Protection | 29 |
| | HP Heat Pump | 30 |
| | OA Outside Air | 30 |
| | PG Parking Garage | 31 |
| | S Space Humidity and Temperature | 31 |
| | MIS Miscellaneous | 32 |
| | Virtual Point Attributes | 32 |
| | Common Virtual Points | 32 |
| 5.0 | Sample Point Sheets and Schematics | 33 |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

1.0 INTRODUCTION

1.1 Definition: Logical Point Mnemonic

An alphanumeric string (name) that is used by the control system to reference any physical attached end device (actuator/sensor etc.) as well as virtual (non-physical) points such as setpoints. The combination of letters and numbers is chosen so as to help one remember the function of the particular point.

1.2 Simple, obvious operation is the key to any successful energy management control system (EMCS). Much of the ease of use is dependent upon the simplicity and consistency of the names chosen to represent the attached sensors and actuators. A balance must be struck between the difficulties associated with always having to key in very long but descriptive names, and the convenience of using a short but more cryptic mnemonic.

1.3 When systems are installed, a significant amount of time is used in the creation of the database and control sequences. Much time is spent later in the fine tuning of the sequences. All this activity necessitates a mnemonic scheme which does not hamper the operator in the understanding of the programmed strategies.

1.4 Most systems offer graphic packages which reduce much of the tedious keyboard entry. At first glance this could imply that there is little need to pay attention to the length of point names. Unfortunately the graphics, however easy to use, must be configured and maintained by someone. In many instances that person is the building operator. Since most operators are chosen for their HVAC/operations knowledge not their keyboarding skills, it is still important to strike a suitable balance.

1.5 A universally applicable scheme is desirable in order to allow operators from various facilities to easily exchange control strategies. Such a standard also decreases the difficulties of staff migration and enables support staff to more easily assist the various areas.

1.6 The purpose of a building control system is to continuously monitor various physical properties and manipulate mechanical devices so as to maintain the desired conditions as determined by the programming. The desired conditions are often indicated by virtual set points relating to the physical property under control. Since all this activity relates to actual physical equipment, it is only reasonable that the mnemonic standard be based on this equipment, not the inner workings of the controller. The name should answer the following questions:

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

- 1) What building (only for multi-building site)?
- 2) What mechanical system ?
- 3) What zone if terminal equipment is associated with the system?
- 4) What end device (i.e. valve, damper, sensor)?
- 5) Does the function of the point require some special emphasis?

1.7 The questions above indicate a three or four level logical point mnemonic and, for some points, an appended fifth level function indicator or attribute.

Level 1: Provides information as to what building contains the point. This level is not required for the usual single building installations.

Level 2: Specifies the mechanical system to which the point is associated.

Level 3: Specifies the point directly associated with the mechanical system described by the level 2 mnemonic.

1.8 There are many cases where the point is not directly associated with the mechanical system described by the level 2 mnemonic, such as in the case of terminal control units that service additional equipment associated with the main system. An example of this is a variable volume air system and its affiliated VAV box controllers.

If the point is connected to terminal equipment affiliated with the system, described by the level 2 mnemonic, then the level 3 mnemonic would describe the type of terminal controller and its location. Level 4 would then be required to specify the point.

Level 3: Specifies the terminal equipment associated with the mechanical system described by the level 2 mnemonic.

Level 4: Specifies the point associated with the terminal equipment described by the level 3 mnemonic.

1.9 If the point represents some associated function with respect to another point or to the system as a whole then an attribute indicator is appended to the previous levels. A separating delimiter is mandatory.

Attribute: Specifies the special function of a physical or virtual point.

1.10 All of the above levels need not be present in a point name. A point name may be composed of as little as two levels; system and point.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

2.0 PHYSICAL POINTS - SPECIFICS

2.1 The logical point mnemonic is to be an alphanumeric code composed of three levels if the point is directly associated with the mechanical system.

BUILDING This level is used only if more than one building is under the control of a single EMCS. A one or two character abbreviation is used to designate each building within the system. Examples:

BB Bowker Building
HB Haultain Building
PW Pedway

SYSTEM This level uses a two character mnemonic to break out the major mechanical systems within the facility. A third character is allowed, but not required, in order to enable like systems to be separated. Examples:

AH1 Air Handler 1
VVS Variable air Volume system South

POINT This level uses a three to four character mnemonic to describe the actual point that is to be controlled. The fourth character is allowed in order to enable the separation of multiple like final control elements or sensors. The additional character is also used in more complex systems where there are many points on a piece of equipment such as a boiler. Examples:

MAT Mixed Air Temperature
CCV Cooling Coil Valve
BSP Branch Static Pressure (if only one)
BSP2 Branch Static Pressure 2
B3HF Boiler 3 High Fire
B2FF Boiler 2 Flame Fail

2.2 The logical point mnemonic will need to be an alphanumeric code composed of four levels if the point is connected to a terminal controller or other associated piece of equipment affiliated with the mechanical system.

BUILDING As above.

SYSTEM As above.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

TERMINAL UNIT This level uses a single character mnemonic to indicate the type of terminal unit (B for Box, etc) followed by up to three characters which are used to separate the units. Examples:

B216 - Box for room 216

TERMINAL POINT This level uses a 1 to 3 character mnemonic to describe the actual point that is to be controlled. These mnemonics follow the same convention as for other point names. Examples:

C Compressor in heat pump unit
CCV Cooling Coil Valve in induction units
D Damper in dual duct or VAV unit
F Fan in fan powered units
HCV Heating Coil Valve in induction units
PRV Perimeter Radiation Valve
RCV Reheat Coil Valve in terminal reheat units
RPV Radiant Panel Valve
RV Reversing valve in heat pump unit
SAF Supply Air Flow rate of VAV unit
SAT Supply Air Temperature of terminal unit
ST Space temperature
V Valve (miscellaneous functions)

2.3 For physical points, appending attributes are most often used to clarify the intended function of the point such as in the naming of status points. Special purpose transducers, where the output cannot be ranged to a proper engineering unit without going through a program, require an appending attribute as well. Example: If AH1SAF is to be the mnemonic for the final calibrated supply air flow rate, then the actual non-linear or uncalibrated physical input point would be named AH1SAF-T. Common attributes:

A Amps - motor or device current from current transducer or drive output.
E Enable - a point that allows a piece of equipment to run under the control of some hardwired local device or its packaged controls.
F Fault - fault alarm from variable speed drive or packaged controller
O Override – device override or local controls override status.
S Status - device status from packaged controller or motor status from differential pressure or current switch etc.
R Reset - setpoint reset to packaged controller (control point adjust).
T Transducer - general nonlinear, uncalibrated or special purpose input.

A delimiter is mandatory so as not to cause confusion with other point mnemonics. For example: AH1SFS Is this supply fan status or supply fan speed ?

The delimiter can be any allowed non-alphanumeric character, but the use of a minus sign “-” or an underscore “_” is highly recommended. If these are not allowed then the forward slash “/” has been found to be an acceptable alternate.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

2.4 The complete logical point mnemonic is formed by combining all levels sequentially. Examples:

LCAH1MAT

| | | | |
|-----|-------|-----------|-----------------------|
| XX | ----- | Building: | Law Courts |
| XXX | ----- | System: | Air Handler #1 |
| XXX | ---- | Point: | Mixed Air Temperature |

LCVVS216SAF

| | | | |
|------|-------|------------|-----------------------|
| XX | ----- | Building: | Law Courts |
| XXX | ----- | System: | Variable Volume South |
| XXXX | --- | Term unit: | Box for room 216 |
| XXX | | Point: | Supply Air Flow rate |

In a single building system the complete logical point mnemonic would omit the first level. Examples:

AH1MAT

| | | | |
|-----|-------|---------|-----------------------|
| XXX | ----- | System: | Air Handler #1 |
| XXX | ----- | Point: | Mixed Air Temperature |

VVSB216SAF

| | | | |
|------|-------|------------|-----------------------|
| XXX | ----- | System: | Variable Volume South |
| XXXX | ----- | Term unit: | Box for room 216 |
| XXX | -- | Point: | Supply Air Flow rate |

BSP1

| | | | |
|----|-------|---------|---------------|
| XX | ----- | System: | Boiler System |
| XX | ----- | Point: | Pump #1 |

BSP1-S

| | | | |
|----|-------|------------|---------------|
| XX | ----- | System: | Boiler System |
| XX | ----- | Point: | Pump #1 |
| X | ----- | Delimiter | |
| X | ----- | Attribute: | Status |

BSB3-E

| | | | |
|----|-------|------------|---------------|
| XX | ----- | System: | Boiler System |
| XX | ----- | Point: | Boiler #3 |
| X | ----- | Delimiter | |
| X | ----- | Attribute: | Enable |

VVSSAF-T

| | | | |
|-----|-------|------------|-----------------------|
| XXX | ----- | System: | Variable Volume South |
| XXX | ----- | Point: | Supply Air Flow rate |
| X | ----- | Delimiter | |
| X | ---- | Attribute: | Transducer |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

2.5 Except for the appending attribute characters, levels within the mnemonics should not be separated by spaces or other punctuation, unless absolutely required by the system. Their addition adds little to comprehension but significantly increases the number of keystrokes used in creating programming or editing database.

2.6 The building portion of the mnemonic is not necessarily for single building applications.

2.7 As a general rule, each character in the logical point mnemonic represents one word used to describe the point. Examples:

| | |
|---------|---|
| AH1CCV | Air Handler 1 (system), Cooling Coil Valve (point) |
| HWSWT | Heating Water (system), Supply Water Temperature (point) |
| VVNMAAD | Variable Volume North (system), Mixed Air Dampers (point) |

2.8 Where glycol is used in place of water, “G” replaces “W”. Example:

| | |
|-------|---|
| BSSWT | Boiler System Supply Water Temperature |
| BSSGT | Boiler System Supply Glycol Temperature |

2.9 There are always a few alarm points, such as an elevator sump level, that are difficult to place with any particular mechanical system. These miscellaneous points are best placed together under system name MIS.

3.0 VIRTUAL POINTS - SPECIFICS

3.1 Definition: Virtual point

A numeric variable (value stored in computer memory), that has associated with it, data similar to that of a real physical point. This variable can be commanded or used in control programs. It can be assigned units as well as any other normal database information but is not a real physical point.

3.2 The basic uses for these points are:

- .1 Global virtual points are used to set building operating modes or calculate values that are used by many systems
- .2 System virtual points associated with physical points or mechanical systems to provide information such as operating flags, setpoints, controller gains, user adjust values and max/min/average/effective space conditions.
- .3 Local virtual points used to hold intermediate calculated information such as factors used in determining setpoints.
- .4 Speciality virtual points that are used in the calculation of information that is further used to produce some global flags or the like. An example would be the point mnemonics used in an outside air temperature projection routine.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

- 3.3 Global virtual points, by their nature, are used in the control sequences of many mechanical systems. They are used to summarize information for operator use and to totalize values, obtained from many smaller systems, for use by a building wide system such as the heating or cooling systems. These points are usually included on at least one graphic screen. Although the way many of these values are determined may be complex, their use is usually obvious. As such, many have been given simple word like mnemonics. The following are some recommended mnemonics that have evolved over time and are in common use:

GLOBAL BUILDING TEMPERATURE TARGETS & OPERATING MODES

| | |
|----------|-----------------------------|
| STOBJ | Space temperature objective |
| STOBJ_UA | STOBJ user adjust |
| OCCUPIED | Occupied mode flag |
| PURGE | Purge mode flag |
| PREHEAT | Preheat mode flag |
| PRECOOL | Precool mode flag |

GLOBAL INFORMATION

| | |
|---------|---|
| HTGDMND | Overall heating demand (sum of all air sys heating demands) |
| CLGDMND | Overall cooling demand (sum of all air sys cooling demands) |
| ST_MAX | Maximum building space temperature in the building |
| ST_AVG | Average building space temperature |
| ST_MIN | Minimum building space temperature |
| ST_EFF | Effective building space temperature |
| CRTIME | Calculated real time (decimal hours) if not provided by control system) |

- 3.4 A larger building is often split into various areas with a dedicated air handling system serving each area. If each of these areas has differing occupancy schedules, it is possible to have a separate set of operating mode flags for each area as follows:

| | |
|-----------|--|
| STOBJ# | Space temperature objective for area # |
| STOBJ#_UA | User adjust for STOBJ for area # |
| OCCUP# | Occupied mode flag for area # |
| PURGE# | Purge mode flag for area # |
| PREHEAT# | Preheat mode flag for area # |
| PRECOOL# | Precool mode flag for area # |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

- 3.5 System virtual points usually relate to some function associated with the control of a physical property. They should be named similarly but with an extension that describes the function being performed. The following appending attribute mnemonics are recommended:

| | | | |
|------|------------------------------|-------|----------------|
| _SP | setpoint | _GO | system go flag |
| _UA | user adjust | _RT | run time |
| _CO | controller | _HL | high limit |
| _PG | controller proportional gain | _LL | low level |
| _IG | controller integral gain | _ALM | alarm |
| _DG | controller derivative gain | _LEAD | lead/lag flag |
| _MAX | maximum | _AVG | average |
| _MIN | minimum | _EFF | effective |

- 3.6 Setpoints and controllers are named after the controlled variable, not the device doing the controlling. (i.e. AH1CCV_SP is meaningless) An example of supply air temperature control follows:

| | |
|-----------|---|
| AH1SAT | Supply Air Temperature (physical point) controlled variable |
| AH1SAT_UA | Supply Air Temp User Adjust (an offset applied to setpoint) |
| AH1SAT_SP | Supply Air Temperature SetPoint |
| AH1SAT_CO | Supply Air Temperature Controller |
| AH1SAT_PG | Supply Air Temperature controller Proportional Gain |

- 3.8 More examples of common system virtual point mnemonics:

| | |
|------------|--|
| AH1_GO | Air Handler 1 GO flag (“yes” to run AH1, “no” to stop AH1) |
| AH1MAD_MIN | Minimum desired position for AH1 mixed air dampers |
| AH1SF_RT | Run time for AH1 supply fan |
| BSRWT_LL | Boiler system return water temperature low limit |
| BSSWT_HL | Boiler system supply water temperature high limit |
| BSRWT_ALM | Boiler system low return water temperature alarm |

- 3.9 As alluded to in global virtuals above, some system points are necessary to pass information that will be summed or manipulated in some fashion by a more global routine. Examples of some of these are:

| | |
|-----------|--|
| AH#CDMND | Cooling demand value from air system AH# |
| AH#HDMND | Heating demand value from air system AH# |
| AH#ST_MAX | Maximum space temperature in zones served by AH# |
| AH#ST_AVG | Average space temperature in zones served by AH# |
| AH#ST_MIN | Minimum space temperature in zones served by AH# |
| AH#ST_EFF | Effective space temperature in zones served by AH# |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

- 3.10 The uses for local virtual points are so varied that no standard can be proposed. Sound judgement should be used in coming up with mnemonics that fit within the overall scheme yet succinctly describe their use. These points are rarely shown on a graphic screens. Since most uses are sufficiently complex, program comments are required to explain their function. As such, long descriptive mnemonics are not required because the program comments should already explain their purpose in detail. Examples:

AH1SAT_SPF1 Factor 1 in the calculation of AH1 Supply Air Temp Setpoint
AH1MAD_OALF Outside air temp linearization multiplication factor.

- 3.11 Over the years some speciality calculations have become somewhat standard and the virtual points mnemonics used have been standardized as well. A good example is the outside temperature projection routine:

SPECIALITY VIRTUAL POINTS

| | |
|---------|--|
| OAT | Temperature selected or calculated for use in projector. |
| OATPHT | Projected high temperature |
| OATPLT | Projected low temperature |
| OATHDH | Hour of day's high temperature |
| OATHDL | Hour of day's low temperature |
| OATYTD | Yesterday's temperature difference |
| OATDH | Day's high |
| OATDL | Day's low |
| WARMDAY | Warm day flag |
| COLDDAY | Cold day flag |

4.0 STANDARD FOR LOGICAL POINT MNEMONICS

The following articles and tables attempt to list the majority of possible point mnemonics for the most common building mechanical systems. It is unlikely that any one mechanical system will contain all the points listed. Some are mutually exclusive (e.g. supply fan vanes and supply fan speed), others are simply not common. It is also unlikely that all necessary point mnemonics will be found in this document. Some creativity will be required to create the new names in such a way as to conform to the basics of this standard. The mnemonics are provided to assist in naming the points used in a particular design, NOT as a guideline to create the design.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

Allowed number of characters:

| BUILDING | SYSTEM | SYS POINT | TERM POINT | ATTRIBUTE |
|----------|--------|-----------|------------|-----------|
| 1-2 | 1-3 | 2-4 | 1-3 | 1-4 |

NOTE: Physical/hardware point attributes such as amps, enable, fault, override, reset, status and transducer are always 1 character in length. Attributes used in virtual points such as setpoint, user adjusts and others are always 2 or more characters in length.

4.1 BUILDING LEVEL MNEMONICS

This level is used only if more than one building is under the control of a single EMCS. A one or two character abbreviation is used to designate each building within the system.

4.2 SYSTEM LEVEL MNEMONICS

This level uses a 2 to 3 character abbreviation to identify a particular mechanical system. A "*" in the following lists indicates that an additional character or number can be used to help identify a specific system when more than one of a particular type exists. E.g. AH1, AH2, AH3 etc.

4.2.1 Air Systems

AH* Air Handler – constant volume single zone or terminal reheat
DD* Dual Duct
IS* Induction System
MU* Makeup air Unit
MZ* MultiZone
VV* Variable air Volume

4.2.2 Cooling Systems

CT* Cooling Tower
CW* Chilled Water
DC* Dry Cooler – subset of points required for CT*

4.2.3 Electrical Systems

LS* Lighting System – used only if there are many lighting points
PD* Power Distribution – includes emergency generator
PL* Parking Lot

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.2.4 Heating Systems

- BA*** Boiler Air – combustion air for boiler room
- BS*** Boiler System – large systems, boilers and supporting equipment
- HE*** Heat Exchanger
- HW*** Heating Water – includes boilers in simpler systems
- PR*** Perimeter Radiation – if complex or on separate loop
- RP*** Radiant Panel – if complex or on separate loop
- TR*** Terminal Reheat – if complex or on separate loop

4.2.5 Other Systems

- CA*** Control Air
- DCW** Domestic Cold Water
- DHW** Domestic Hot Water
- FA** Fire Alarm – may include smoke exhaust points
- FP** Fire Protection – Sprinklers etc. – may be rolled into fire alarm system
- HP** Heat Pump
- OA*** Outside Air information – temp, hum, projected conditions etc.
- PG*** Parking Garage – combines CO sensors, exhaust fans and makeup units
- SH*** Space Humidity – if monitoring/controlling separate spaces (museums)
- ST*** Space Temperature – if not associated with any particular air system
- MIS** Miscellaneous – for odd points that don't fit in elsewhere
 - e.g. elevator sump alarms,

4.3 POINT LEVEL MNEMONICS

The actual point mnemonic portion may consist of up to three levels depending on how the point relates to the mechanical system. A physical point directly associated with a system would consist of a single level representing the point with 2-4 characters. A terminal point will require a 2-4 character terminal box identifier followed by 1-3 characters representing the actual point. Finally, any of these can be followed by an appending attribute.

In any case, room has been left for an additional number or letter to distinguish multiple like points. For example, if an air system has two supply fans then one would likely be named SF1, the other SF2. In a similar fashion, if a wetted media humidifier were split into three sections with a solenoid for each portion, then the solenoids would be named SH1, SH2, SH3.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.1 Physical Point Attributes

NOTE: The reference to a VAV system speed drive and supply air flow rate is included only to provide a context for the attribute examples.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|----------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| | | | | <i>VAV air system</i> | |
| | | | | <i>Supply Fan (speed drive)</i> | |
| SF | | E | DO | Enable | VV VVSF VVSF-E |
| SF | | S | DI | Status | VVSF-S |
| SF | | F | DI | Fault | VVSF-F |
| SF | | O | DI | Override (drive in local manual ctrl) | VVSF-O |
| SF | | A | AI | Amps | VVSF-A |
| SFS | | | AO | Supply Fan Speed | VVSFS |
| SAF | | T | AI | Transmitter (Raw Data) - used when input requires program manipulation to provide usable value | VVSAF-T |

4.3.2 Air System: AH* (Air Handler – Self Contained Packaged Controls)

Some small air systems and most gas fired makeup air units contain their own packaged control system. These usually allow external start/stop or enable control and usually provide contacts for system status and possibly an alarm. Most can also be fitted so as to accept an external signal for resetting the system's supply air temperature setpoint. The following provides mnemonics for EMCS points interfacing to these packaged control systems:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--|----------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| | | | | <i>Air System</i> | |
| | | | | System Enable (packaged controls) | AH1 |
| | | E | DO | System Enable (packaged controls) | AH1-E |
| | | S | DI | System Status (packaged controls) | AH1-S |
| | | F | DI | System Fault (packaged controls) | AH1-F |
| MAD | | O | DO | Mix Dampers - Economizer Override - wired into controls package | AH1MAD-O |
| SAT | | | AI | Supply Air Temperature | AH1SAT |
| | | R | AO | SetPoint Reset (packaged controls) | AH1-R |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.3 Air System: AH* (Air Handler – Single Zone or Terminal Reheat)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-------------------------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| SF | | | DO | Supply Fan | AH1SF |
| SFH | | | DO | Supply Fan High Speed | AH1SFH, AH1SFH2 |
| SFL | | | DO | Supply Fan Low Speed | AH1SFL, AH1SFL2 |
| RF | | | DO | Return Fan | AH1RF2 |
| RFH | | | DO | Return Fan High Speed | AH1RFH, AH1RFH2 |
| RFL | | | DO | Return Fan Low Speed | AH1RFL, AH1RFL2 |
| EF | | | DO | Exhaust Fan | AH1EF, AH1EF4 |
| CCP | | | DO | Cooling Coil Pump | AH1CCP |
| HCP | | | DO | Heating Coil Pump | AH1HCP |
| PCP | | | DO | Preheat Coil Pump | AH1PCP |
| DX | | | DO | Direct Expansion Cooling Solenoid | AH1DX, AH1DX2 |
| DXC | | E | DO | DX Compressor – Enable (pkg ctrls) | AH1DXC-E |
| SH | | | DO | Spray Humidifier Solenoid | AH1SH, AH1SH3 |
| SF | | S | DI | Supply Fan – Status | AH1SF-S |
| SFH | | S | DI | Supply Fan High Speed – Status | AH1SFH-S |
| SFL | | S | DI | Supply Fan Low Speed – Status | AH1SFL-S |
| RF | | S | DI | Return Fan – Status | AH1RF2-S |
| RFH | | S | DI | Return Fan High Speed – Status | AH1RFH2-S |
| RFL | | S | DI | Return Fan Low Speed – Status | AH1RFL2-S |
| EF | | S | DI | Exhaust Fan – Status | AH1EF-S |
| FP | | | DI | Freeze Protect (stat) | AH1FP |
| SAT | | | AI | Supply Air Temperature | AH1SAT |
| MAT | | | AI | Mixed Air Temperature | AH1MAT |
| RAT | | | AI | Return Air Temperature | AH1RAT |
| PHT | | | AI | Preheat Air Temperature | AH1PHT |
| SAH | | | AI | Supply Air Humidity | AH1SAH |
| RAH | | | AI | Return Air Humidity | AH1RAH |
| ST | | | AI | Space Temp (if not terminal equip.) | AH1ST1, AH1ST3 |
| CCV | | | AO | Cooling Coil Valve | AH1CCV |
| HCV | | | AO | Heating Coil Valve | AH1HCV |
| PCV | | | AO | Preheat Coil Valve | AH1PCV |
| HV | | | AO | Humidifier Valve (steam) | AH1HV |
| MAD | | | AO | Mixed Air Dampers | AH1MAD |
| FAD | | | AO/DO | Fresh Air Damper | AH1FAD |
| RD | | | AO/DO | Relief Damper | AH1RD |
| FBD | | | AO | Face and Bypass Dampers | AH1FBD |
| Z*** | | | | Zone *** Terminal Equipment | AH1Z305 |
| | | | | - designate by room # or location | |
| → | ST | | AI | Space Temperature | AH1Z305ST |
| → | SAT | | AI | Supply Air Temperature | AH1Z305SAT |
| → | RCV | | AO | Reheat Coil Valve | AH1Z305RCV |
| → | PRV | | AO | Perimeter Radiation Valve and/or | AH1Z305PRV |
| → | RPV | | AO | Radiant Panel Valve as applicable | AH1Z305RPV |

Note: Single zone air systems do not require items in “Terminal Point” column.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.4 Air System: DD* (Dual Duct)

Includes most of the system point mnemonics under AH plus the following:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| CDT | | | AI | Cold Deck Temperature | DDNCDT |
| HDT | | | AI | Hot Deck Temperature | DDNHDT |
| DDP | | | AI | Duct Differential Pressure | DDNDDP |
| CDV | | | AO | Cold Deck Valve | DDNCDV |
| HDV | | | AO | Hot Deck Valve | DDNHDV |
| B*** | | | | Box *** Terminal Equipment - designate by room # or location | DDNZ508 |
| | | | | | |
| → | ST | | AI | Space Temperature | DDNZ508ST |
| → | SAT | | AI | Supply Air Temperature | DDNZ508SAT |
| → | SAF | | AI | Supply Air Flow Rate (for DD VAV) | DDNZ508SAF |
| → | D | | AO | Box Mixing Damper | DDNZ508D |
| → | CDD | | AO | Cold Duct Damper (for DD VAV) | DDNZ508CDD |
| → | HDD | | AO | Hot Duct Damper (for DD VAV) | DDNZ508HDD |

4.3.5 Air System: IS* (Induction System)

Includes most of the system point mnemonics under AH plus the following:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--|------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| U*** | | | | Unit *** Terminal Equipment - designate by room # or location | IS2Z508 |
| | | | | | |
| → | ST | | AI | Space Temperature | IS2Z508ST |
| → | SAT | | AI | Supply Air Temperature | IS2Z508SAT |
| → | V | | AO | Coil Valve | IS2Z508SAF |

4.3.6 Air System: MU* (Make-up air Unit)

Includes most of the system point mnemonics under AH.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.7 Air System: MZ* (Multizone)

Includes most of the system point mnemonics under DD plus the following:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------------------------|----------------|---------|----------------|--|--|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| DHS DLS | | | AI AI | Damper High Select Damper Low Select (these are rarely used anymore) | MZ1DHS MZ1DLS |
| Z*** → → → | ST SAT D | | AI AI AO | Zone *** - designate sequentially by zone # Space Temperature Supply Air Temperature (not common) Zone Mixing Damper | MZ2Z1, MZ2Z2, MZ2Z3 MZ1Z3ST MZ1Z3SAT MZ1Z3D |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.8 Air System: VV* (Variable air Volume)

Includes most of the system point mnemonics under AH plus the following:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| SF | | | DO | Supply Fan | VV2SF |
| RF | | | DO | Return Fan | VV2RF |
| SF | | E | DO | Supply Fan – Enable (speed drive) | VV1SF-E |
| RF | | E | DO | Return Fan – Enable (speed drive) | VV1RF-E |
| SF | | S | DI | Supply Fan – Status | VV2SF-S |
| RF | | S | DI | Return Fan – Status | VV2RF-S |
| SF | | F | DI | Supply Fan – Fault (speed drive) | VV1SF-F |
| RF | | F | DI | Return Fan – Fault (speed drive) | VV1RF-F |
| SF | | A | AI | Supply Fan – Amps | VV1SF-A |
| RF | | A | AI | Return Fan – Amps | VV1RF-A |
| SVP | | | AI | Supply Velocity Pressure | VV1SVP, VV3SVP2 |
| RVP | | | AI | Return Velocity Pressure | VV1RVP, VV2RVP2 |
| SAF | | | AI | Supply Air Flow Rate | VV1SAF |
| RAF | | | AI | Return Air Flow Rate | VV1RAF |
| BSP | | | AI | Branch Static Pressure | VV1BSP |
| BDP | | | AI | Building Differential Pressure | VV1BDP |
| SFV | | | AO | Supply Fan Vanes | VV3SFV |
| RFV | | | AO | Return Fan Vanes | VV3RFV |
| SFP | | | AO | Supply Fan Pitch | VV2SFP |
| RFP | | | AO | Return Fan Pitch | VV2RFP |
| SFS | | | AO | Supply Fan Speed | VV1SFS |
| RFS | | | AO | Return Fan Speed | VV1RFS |
| B*** | | | | Box *** Terminal Equipment - designate by room # or location | VV1Z229 |
| | | | | | |
| → | F | | DO | Fan | VV1Z229F |
| → | ST | | AI | Space Temperature | VV1Z229ST |
| → | SAT | | AI | Supply Air Temperature | VV1Z229SAT |
| → | SVP | | AI | Supply Velocity Pressure | VV1Z229SVP |
| → | SAF | | AI | Supply Air Flow Rate | VV1Z229SAF |
| → | D | | AO | Flow Control Damper | VV1Z229D |
| → | PRV | | AO | Perimeter Radiation Valve | VV1Z229PRV |
| → | RPV | | AO | Radiant Panel valve | VV1Z229RPV |
| → | RCV | | AO | Reheat Coil Valve | VV1Z229RCV |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.9 Cooling System: CT* / DC* (Cooling Tower / Dry Cooler)

The dry cooler mnemonics are a subset of those required for a cooling tower.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-------------------------------------|------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| F | | | DO | Fan (single speed) | CTF, CT2F, CT2F1 |
| FH | | | DO | Fan High Speed | CTFH, CT2FH1 |
| FL | | | DO | Fan Low Speed | CTFL, CT2FL1 |
| F | | E | DO | Fan – Enable (speed drive) | CT1F-E, CT2F1-E |
| P | | | DO | Pump | CTP1, CTP2 |
| D | | | DO | Dump (valves/solenoids) | CTD, CT2D |
| BH | | | DO | Basin Heater | CTBH, CT2BH |
| HT | | | DO | Heat Trace | CTHT, CT2HT |
| F | | S | DI | Fan – Status | CT2F-S |
| FH | | S | DI | Fan High Speed – Status | CTFH-S, CT2FH1-S |
| FL | | S | DI | Fan Low Speed – Status | CTFL-S, CT2FL-S |
| F | | F | DI | Fan – Fault (speed drive) | CT1F-F |
| P | | S | DI | Pump Status | CTP1-S, CTP2-S |
| BL | | | DI | Basin Level (level alarm) | CTBL |
| F | | A | AI | Fan – Amps | CT1F-A |
| SWT | | | AI | Supply (tower leaving) Temperature | CT1SWT |
| RWT | | | AI | Return (tower entering) Temperature | CT1RWT |
| BT | | | AI | Basin Temperature | CT1BT |
| FS | | | AO | Fan Speed | CT1FS |
| FOD | | | AO | Fan Outlet Damper | CTFOD, CTFOD2 |
| BPV | | | AO | Bypass Valve | CTBPV |
| CV | | | AO | Control Valve | CTCV |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.10 Cooling System: CW* (Chilled Water)

Since many points are associated with each chiller, it is possible to treat an individual chiller in the same manner as terminal equipment.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|-------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump (general) | CWP1, CWP2 |
| P | | E | DO | Pump – Enable (speed drive) | CWP-E |
| PP | | | DO | Primary Pump | CWPP, CWPP1 |
| PP | | E | DO | Primary Pump – Enable (speed drive) | CWPP-E, CWPP1-E |
| SP | | | DO | Secondary Pump | CWSP, CWSP1 |
| SBP | | | DO | Stand-by Pump | CWSBP |
| ISP | | | DO | Ice Storage Pump | CWISP |
| P | | S | DI | Pump (general) – Status | CWP1-S, CWP2-S |
| P | | F | DI | Pump – Fault (speed drive) | CWP1-F |
| PP | | S | DI | Primary Pump – Status | CWPP-S, CWPP1-S |
| PP | | F | DI | Primary Pump – Fault (speed drive) | CWPP-F, CWPP1-F |
| SP | | S | DI | Secondary Pump – Status | CWSP-S, CWSP1-S |
| SBP | | S | DI | Stand-by Pump – Status | CWSBP-S |
| ISP | | S | DI | Ice Storage Pump – Status | CWISP-S |
| ISL | | | DI | Ice Storage Level (level alarm) | CWISL |
| ET | | | DI | Expansion Tank (level alarm) | CWET |
| FS | | | DI | Flow Switch (general) | CWFS |
| P | | | AI | Pump (general) – Amps | CWP1-A |
| SWT | | | AI | Supply Water Temperature | CWSWT |
| RWT | | | AI | Return Water Temperature | CWRWT |
| SSP | | | AI | Supply Static Pressure | CWSSP |
| SWF | | | AI | Supply Water Flow Rate | CWSWF |
| IST | | | AI | Ice Storage Supply Temperature | CWIST |
| IRT | | | AI | Ice Storage Return Temperature | CWIRT |
| ISS | | | AI | Ice Storage Sensor | CWISS |
| PS | | | AO | Pump Speed | CWPS |
| PPS | | | AO | Primary Pump Speed | CWPPS |
| C# | | | | Chiller # | CWC, CWC1, CWC2 |
| | | | | - designate by chiller # | |
| → | S | | DO | Compressor Stage | CWCS2, CWC1S1 |
| → | | E | DO | Chiller – Enable (packaged controls) | CWC-E, CWC1-E |
| → | S | S | DI | Compressor Stage – Status | CWCS1-S, CWC1S1-S |
| → | | S | DI | Chiller – Status (packaged controls) | CWC1-S |
| → | | F | DI | Chiller – Fault (packaged controls) | CWC1-F |
| → | | A | AI | Chiller – Current Draw (amps) | CWC1-A |
| → | | R | AO | Chiller – SetPoint Reset (pkg controls) | CWC1-R |
| → | LL | | AO | Chiller – Load Limit | CWC1LL |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.11 Electrical System: LS* (Lighting System)

Use this system only if there are a large number of lighting points, otherwise include the few lighting zones under PD (Power distribution).

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|--------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| E | | | DO | Exterior Lighting - provide face or area information | LSE, LSE1, LSESW |
| PL | | | DO | Parking Lot | LSPL, LSPL2, LSPLS |
| Z | | | DO | Zone – lighting control - provide floor and room or area | LSZ305, LSZ3NE |
| S | | | DI | Zone – switch input - provide floor and room or area | LSS305, LSS3NE |
| PC | | | DI | Photocell (day/night status) | LSPC |

4.3.12 Electrical System: PL* (Parking Lot)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--------------|-----------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| L | | | DO | Lot Lighting | PLL, PL1L, PLNL, PLSL |
| O | | | DO | Lot Outlets | PLO, PLO1, PLO2 |

4.3.13 Electrical System: PD* (Power Distribution)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|---------------------------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| LZ | | | DO | Lighting Zone (for a few zones only) - indicate interior/exterior/room or area | PDLZ1, PDLZE, PDLZ3W, PDLZ402 |
| GDT | | | DI | E Generator Day Tank (level alarm) | PDGDT, PDGDT2 |
| GMT | | | DI | E Generator Main Tank (level alarm) | PDGMT |
| GTS | | | DI | E Generator Transfer Switch | PDGTS, PDGTS1 |
| G | | S | DI | E Generator Status | PDG-S, PDG1-S |
| G | | F | DI | E Generator Fault (alarm) | PDG-F, PDG1-F |
| CT | | | AI | Current Transformer (one / phase) | PDCT1, PDCT2, PDCT3 |
| PT | | | AI | Potential Transformer (one / phase) - for feeder "n" phase "#" | PDPT1, PDPT2, PDPT3 PDCTn#, PDPTn# |
| WM | | | AI | Watt Meter | PDWM, PDWM2 |
| ERT | | | AI | Electrical Room Temperature | PDERT, PDERT019 |
| TT | | | AI | Transformer Temperature | PDTT, PDTT019 |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.14 Heating System: BA* (Boiler combustion Air)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|----------------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| F | | | DO | Fan | BAF, BAF2, BAF3 |
| F | | E | DO | Fan – Enable (speed drive) | BAF-E |
| F | | S | DI | Fan – Status | BAF-S, BAF2-S |
| F | | F | DI | Fan – Fault (speed drive) | BAF-F |
| SAT | | | AI | Supply Air Temperature | BASAT |
| BRT | | | AI | Boiler Room Temperature | BABRT |
| BRP | | | AI | Boiler Room Pressure | BABRP |
| HCV | | | AO | Heating Coil Valve | BAHCV |
| FS | | | AO | Fan Speed | BAFS |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.15 Heating System: BS* (Boiler System)

This system mnemonic is intended for large or complicated systems with many boilers. Since many points are associated with each boiler, it is possible to treat an individual boiler in the same manner as terminal equipment. This also makes it possible to use the same naming scheme in smaller systems where the boiler points are included in the Heating Water system.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--|--------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump (general) | BSP, BSP2, BSP7 |
| CP | | | DO | Condensate Pump | BSCP |
| FWP | | | DO | Feedwater Pump | BSFWP |
| PP | | | DO | Primary Pump | BSPP1, BSPP2 |
| P | | S | DI | Pump – Status (general) | BSP-S, BSP2-S |
| CP | | S | DI | Condensate Pump – Status | BSCP-S |
| FWP | | S | DI | Feedwater Pump – Status | BSFWP –S |
| PP | | S | DI | Primary Pump – Status | BSPP1-S, BSPP2-S |
| CT | | | DI | Condensate Tank (level alarm) | BSCT |
| ET | | | DI | Expansion Tank (level alarm) | BSET |
| FS | | | DI | Flow Switch (general) | BSFS |
| SWT | | | AI | Supply Water Temperature | BSSWT |
| RWT | | | AI | Return Water Temperature | BSRWT |
| MSP | | | AI | Mains Steam Pressure | BSMSP |
| MSF | | | AI | Mains Steam Flow Rate | BSMSF |
| DP | | | AI | Differential Pressure | BSDP |
| GM | | | AI/DI | Gas Meter (pulse or other input) | BSGM |
| PBV | | | AO | Pressure Bypass valve | BSPBV |
| B# | | | | Boiler # | BSB, BSB1, BSB5 |
| | | | | - designate by boiler # | |
| → | | | DO | single stage boiler direct control | BSB, BSB1, BSB5 |
| → | HF | | DO | Boiler High Fire | BSB1HF, BSB2HF |
| → | LF | | DO | Boiler Low Fire | BSB1LF, BSB2LF |
| → | P | | DO | Boiler circ Pump | BSBP, BSB1P, BSB5P |
| → | | E | DO | Boiler – Enable (packaged controls) | BSB-E, BSB3-E |
| → | FS | | DI | Boiler Flow Switch | BSBFS, BSB3FS |
| → | FF | | DI | Boiler Flame Failure | BSBFF, BSB3FF |
| → | | S | DI | Boiler – Status (packaged controls) | BSB1-S |
| → | | F | DI | Boiler – Fault (packaged controls) | BSB1-F |
| → | ST | | AI | Boiler Supply Temperature | BSB1ST, BSB2ST |
| → | GV | | AO | Gas Valve (direct control) | BSB1GV, BSB2GV |
| → | FR | | AO | Firing Rate (indirect control) | BSB1FR |
| | | R | AO | Boiler – SetPoint Reset (pkg controls) | BSB1-R |

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.16 Heating System: HE* (Heat Exchanger)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|----------------------------------|-------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump (general) | HE1P, HENP2 |
| HCP | | | DO | Heating Coils Pump | HEHCP, HEHCP2 |
| PCP | | | DO | Preheat Coils Pump | HEPCP1, HEPCP2 |
| SBP | | | DO | Stand-by Pump | HESBP |
| as ↑ | | E | DO | Pump (speed drive) – Enable | HEP-E, HEHCP-E |
| P | | S | DI | Pump (general) – Status | HEP-S, HEP2-S |
| HCP | | S | DI | Heating Coils Pump – Status | HEHCP-S, HEHCP2-S |
| PCP | | S | DI | Preheat Coils Pump – Status | HEPCP-S, HEPCP2-S |
| SBP | | S | DI | Stand-by Pump – Status | HESBP-S |
| as ↑ | | S | DI | Pump (speed drive) – Status | HEP-S, HEPRP-S |
| as ↑ | | F | DI | Pump (speed drive) – Fault | HEP-F, HEPRP-F |
| ET | | | DI | Expansion Tank (level alarm) | HEET, HEET2 |
| SWT | | | AI | Supply Water Temperature | HESWT |
| RWT | | | AI | Return Water Temperature | HERWT |
| HCST | | | AI | Heating Coils Supply Temperature | HEHCST |
| PCST | | | AI | Preheat Coils Supply Temperature | HEPCST |
| V | | | AO | Control Valve | HEV |
| SV | | | AO | Steam Valve | HESV |
| HCV | | | AO | Heating Coils Valve | HEHCV |
| PCV | | | AO | Preheat Coils Valve | HEPCV |
| as ↑ | | | AO | Pump (speed drive) – Speed | HEPS, HERPPS |

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.17 Heating System: HW* (Heating Water)

It is intended that this system mnemonic contain the distribution heating systems for typical applications. For simple buildings it can also include many of the boiler points under BS and possibly some points under HE etc.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-----------------------------------|-------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump (general) | HWP, HWP2 |
| P | | | DO | Secondary Pump | HWSP, HWSP2 |
| HCP | | | DO | Heating Coils Pump | HWHCP, HWHCP2 |
| PCP | | | DO | Preheat Coils Pump | HWPCP, HWPCP2 |
| RCP | | | DO | Reheat Coils Pump | HWRCP, HWRCP2 |
| PRP | | | DO | Perimeter Radiation Pump | HWPRP, HWPRP2 |
| RPP | | | DO | Radiant Panels Pump | HWRPP, HWRPP2 |
| SBP | | | DO | Stand-by Pump | HWSBP |
| as ↑ | | E | DO | Pump (speed drive) – Enable | HWP-E, HWPRP-E |
| P | | S | DI | Pump (general) – Status | HWP-S, HWP2-S |
| P | | S | DI | Secondary Pump – Status | HWSP-S, HWSP2-S |
| HCP | | S | DI | Heating Coils Pump – Status | HWHCP-S, HWHCP2-S |
| PCP | | S | DI | Preheat Coils Pump – Status | HWPCP-S, HWPCP2-S |
| RCP | | S | DI | Reheat Coils Pump – Status | HWRCP-S, HWRCP2-S |
| PRP | | S | DI | Perimeter Radiation Pump – Status | HWPRP-S, HWPRP2-S |
| RPP | | S | DI | Radiant Panels Pump – Status | HWRPP-S, HWRPP2-S |
| SBP | | S | DI | Stand-by Pump – Status | HWSBP-S |
| as ↑ | | S | DI | Pump (speed drive) – Status | HWP-S, HWPRP-S |
| as ↑ | | F | DI | Pump (speed drive) – Fault | HWP-F, HWPRP-F |
| ET | | | DI | Expansion Tank (level alarm) | HWET, HWET2 |
| SWT | | | AI | Supply Water Temperature | HWSWT |
| RWT | | | AI | Return Water Temperature | HWRWT |
| HCST | | | AI | Heating Coils Supply Temperature | HWHCST |
| PCST | | | AI | Preheat Coils Supply Temperature | HWPCST |
| RCST | | | AI | Reheat Coils Supply Temperature | HWRCSST |
| PRST | | | AI | Perimeter Radiation Supply Temp. | HWPRST |
| RPST | | | AI | Radiant Panels Supply Temperature | HWRPST |
| DP | | | AI | Differential Pressure | HWDP |
| V | | | AO | Control Valve | HWV |
| HCV | | | AO | Heating Coils Valve | HWHCV |
| PCV | | | AO | Preheat Coils Valve | HWPCV |
| RCV | | | AO | Reheat Coils Valve | HWRCV |
| PRV | | | AO | Perimeter Valve | HWPRV |
| RPV | | | AO | Radiant Panels Valve | HWRPV |
| PBV | | | AO | Pressure Bypass Valve | HWPBV |
| as ↑ | | | AO | Pump (speed drive) – Speed | HWPS, HWRPPS |

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.18 Heating System: PR* (Perimeter Radiation)

Use this system mnemonic for complex/multiple perimeter radiation systems or where the addition of these points to HW* would make it unwieldy. For simple buildings these points are usually included under HW as described previously.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-------------------------|-------------|-------------|------------|------------------------------|--|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P as ↑ | | E | DO | Pump | PRP, PR2P1, PRNP2 PRP-E, PR2P1-E |
| | | | DO | Pump (speed drive) – Enable | |
| P as ↑ as ↑ ET | | S S F | DI | Pump – Status | PRP-S, PR2P1-S PRP-S, PR2RP1-S PRP-F, PR2P1-F PRET, PRNET |
| | | | DI | Pump (speed drive) – Status | |
| | | | DI | Pump (speed drive) – Fault | |
| | | | DI | Expansion Tank (level alarm) | |
| SWT RWT DP | | | AI | Supply Water Temperature | PRSWT, PR2SWT PRRWT, PR2RWT RPDP |
| | | | AI | Return Water Temperature | |
| | | | AI | Differential Pressure | |
| V PBV as ↑ | | | AO | Control Valve | PRV RPPBV PRPS, PR2P1S |
| | | | AO | Pressure Bypass Valve | |
| | | | AO | Pump (speed drive) – Speed | |

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

4.3.19 Heating System: RP* (Radiant Panel)

Use this system mnemonic for complex/multiple radiant panel systems or where the addition of these points to HW* would make it unwieldy. For simple buildings these points are usually included under HW as described previously.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-------------------------|-------------|-------------|------------|------------------------------|--|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P as ↑ | | E | DO | Pump | RPP, RP2P1, RPNP2 RPP-E, RP2P1-E |
| | | | DO | Pump (speed drive) – Enable | |
| P as ↑ as ↑ ET | | S S F | DI | Pump – Status | RPP-S, RP2P1-S RPP-S, RP2RP1-S RPP-F, RP2P1-F RPET, RPNET |
| | | | DI | Pump (speed drive) – Status | |
| | | | DI | Pump (speed drive) – Fault | |
| | | | DI | Expansion Tank (level alarm) | |
| SWT RWT DP | | | AI | Supply Water Temperature | RPSWT, RP2SWT RPRWT, RP2RWT RPDP |
| | | | AI | Return Water Temperature | |
| | | | AI | Differential Pressure | |
| V PBV as ↑ | | | AO | Control Valve | RPV RPPBV RPPS, RP2P1S |
| | | | AO | Pressure Bypass Valve | |
| | | | AO | Pump (speed drive) – Speed | |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

4.3.20 Heating System: TR* (Terminal Reheat)

Use this system mnemonic for complex/multiple terminal reheat systems or where the addition of these points to HW* would make it unwieldy. For simple buildings these points are usually included under HW as described previously.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|---------------------------------|-------------|-------------|------------|------------------------------|--|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P as ↑ | | E | DO | Pump | TRP, TR2P1, TRNP2 TRP-E, TR2P1-E |
| | | | DO | Pump (speed drive) – Enable | |
| P as ↑ as ↑ as ↑ ET | | S S F | DI | Pump – Status | TRP-S, TR2P1-S TRP-S, TR2RP1-S TRP-F, TR2P1-F TRET, TRNET |
| | | | DI | Pump (speed drive) – Status | |
| | | | DI | Pump (speed drive) – Fault | |
| | | | DI | Expansion Tank (level alarm) | |
| SWT RWT DP | | | AI | Supply Water Temperature | TRSWT, TR2SWT TRRWT, TR2RWT TRDP |
| | | | AI | Return Water Temperature | |
| | | | AI | Differential Pressure | |
| V PBV as ↑ | | | AO | Control Valve | TRV TRPBV TRPS, TR2P1S |
| | | | AO | Pressure Bypass Valve | |
| | | | AO | Pump (speed drive) – Speed | |

NOTE: For glycol systems use “G” (glycol) in place of “W” (water).

4.3.21 Other Systems: CA* (Control Air)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-------------------------------------|-------------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| C NS | | | DO | Compressor (control or lead select) | CAC1, CAC2 CANS |
| | | | DO | Night Setback | |
| C D | | S F | DI | Compressor – Status | CAC1-S, CSC2-S CAD-F |
| | | | DI | Dryer – Fault | |
| P TP | | | DI/AI | Pressure | CAP CATP |
| | | | DI/AII | Tank Pressure | |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.22 Other Systems: DCW (Domestic Cold Water)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump | DCWP, DCWP2 |
| P | | S | DI | Pump – Status | DCWP-S, DCWP2-S |
| CWP | | | AI | City Water Pressure | DCWCWP |
| TP | | | AI | Tank Pressure | DCWTP |

4.3.23 Other Systems: DHW (Domestic Hot Water)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-------------------------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DO | Pump | DHWP, DHWP2 |
| P | | S | DI | Pump – Status | DHWP-S, DHWP2-S |
| SWT | | | AI | Supply Water Temperature | DHWSWT |
| RWT | | | AI | Return Water temperature | DHWRWT |
| TT | | | AI | Tank Temperature | DHWTT |
| HST | | | AI | High Supply Temp (dish washer etc.) | DHWHST |
| HTT | | | AI | High Tank Temp | DHWHTT |
| V | | | AO | Valve (general) | DHWV |
| HEV | | | AO | Heat Exchanger Valve | DHWHEV |
| MV | | | AO | Mixing Valve | DHWMV |
| SV | | | AO | Steam Valve | DHVSV |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.24 Other Systems: FA* (Fire Alarms)

The mnemonic should provide information as to the area served by the fire alarm point. Examples:

```
FA2NW
XX ----- System:      Fire Alarms
  XXX ----- Area:      2nd Floor Northwest
```

```
FA302
XX ----- System:      Fire Alarms
  XXX ----- Area:      Room 302
```

A multi-building site mnemonic must include the building designation. Example:

```
FABB2NW
XX ----- System:      Fire Alarms
  XX ----- Building:   Bowker Building
    XXX ----- Area:    2nd Floor Northwest
```

NOTE: Fire alarm points are usually added for monitoring purposes or for smoke control. Only fire rated control systems are allowed to use these for other functions such as fan shut down etc.

4.3.25 Other Systems: FP* (Fire Protection)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-----------------------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| P | | | DI | Fire Pump | FPP, FPP1, FPP2 |
| SV | | | DI | Sprinkler Valve | FPSV |
| SP | | | DI/AI | Sprinkler Pressure | FPSP |
| TL | | | DI/AI | Tank Level (fire storage tank) | FPTL |
| TP | | | DI/AI | Tank Pressure (fire storage tank) | FPTP |

NOTE: These points are usually added for monitoring and callout purposes only.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.26 Other Systems: HP (Heat Pump)

This mnemonic encompasses only the actual heat pump loop, heat injection and heat rejection control valves as well as the actual heat pump units. The boilers and dry cooler or cooling tower systems should be treated separately under BS, HW, DC or CT.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|--------------|-------------|---------|------------|--|--------------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| LP | | | DO | Loop Pump | HPLP1, HPLP2 |
| LP ET | | S | DI DI | Loop Pump – Status Expansion Tank (level alarm) | HPLP1-S, HPLP2-S HPET |
| LST LRT | | | AI AI | Loop Supply Water Temperature Loop Return Water temperature | HPLST HPLRT |
| LHIV LHRV | | | AO AO | Loop Heat Injection Valve Loop Heat Rejection Valve | HPLHIV HPLHRV |
| U*** | | | | Unit *** Heat Pump Unit - designate by room # or location | HPU229 |
| | | | | | |
| → | C | | DO | Compressor | HPU229C |
| → | F | | DO | Fan | HPU229F |
| → | FH | | DO | Fan High Speed | HPU229FH |
| → | FL | | DO | Fan Low Speed | HPU229FL |
| → | RV | | DO | Reversing Valve | HPU229RV |
| → | ST | | AI | Space Temperature | HPU229ST |
| → | SAT | | AI | Supply Air Temperature | HPU229SAT |

4.3.27 Other Systems: OA* (Outside Air)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|-------------------|-----------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| T | | | AI | Temperature | OAT, OAT1, OAT2 |
| H | | | AI | Relative Humidity | OAH, OAH1, OAH2 |
| WD | | | AI | Wind Direction | OAWD |
| WS | | | AI | Wind Speed | OAWS |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.28 Other Systems: PG* (Parking Garage)

This mnemonic can be used to combine the various systems used in parkade CO sensing and ventilation. Since many points may be associated with each make-up air unit, it is possible to treat each such unit in the same manner as terminal equipment.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|-------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| EF | | | DO | Exhaust Fan | PGEF1, PGWEF2 |
| EFH | | | DO | Exhaust Fan High Speed | PGEFH, PGEFH3 |
| EFL | | | DO | Exhaust Fan Low Speed | PGEFL, PGEFL3 |
| EF | | | DO | Exhaust Fan (speed drive) – Enable | PGEF-E, PGWEF-E |
| EF | | S | DI | Exhaust Fan – Status | PGEF1-S, PGWEF2-S |
| EFH | | S | DI | Exhaust Fan High Speed – Status | PGEFH-S, PGEFH3-S |
| EFL | | S | DI | Exhaust Fan Low Speed – Status | PGEFL-S, PGEFL3-S |
| EF | | S | DI | Exhaust Fan (speed drive) – Status | PGSF-S, PGEF1-S |
| EF | | F | DI | Exhaust Fan (speed drive) – Fault | PGSF-F, PGEF1-F |
| DP | | | AI | Differential Pressure | PGDP, PGWDP3 |
| EFS | | | AO | Exhaust Fan Speed (speed drive) | PGEFS, PGWEF2S |
| MU# | | | | Make-up Unit # - designate by unit # | PGMU, PGWU1 |
| | | | | | |
| → | | | | | |
| → | FH | | DO | MU Unit Fan High Speed | PGMU1FH |
| → | FL | | DO | MU Unit Fan Low Speed | PGMU2FL |
| → | | E | DO | MU Unit – Enable (packaged ctrls) | PGMU1-E |
| → | | | | | |
| → | FH | S | DI | MU Unit Fan High Speed – Status | PGMU1FH-S |
| → | FL | S | DI | MU Unit Fan Low Speed – Status | PGMU2FL-S |
| → | | S | DI | MU Unit – Status (packaged ctrls) | PGMU1-S |
| → | | F | DI | MU Unit – Fault (packaged ctrls) | PGMU1-F |
| → | SAT | | AI | MU Unit Supply Air Temperature | PGMUSAT |
| → | | R | AO | MU Unit SetPoint Reset (pkg controls) | PGMU1-R |

4.3.29 Other Systems: S* (Space Humidity and Temperature)

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--|----------------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| H | | | AI | Space Relative Humidity - designate by room # or location | SH903, SH8NW SH2E, SH3I |
| T | | | AI | Space Temperature - designate by room # or location | ST902, ST8NW ST2W, ST5I |

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

4.3.30 Other Systems: MIS (Miscellaneous)

This system mnemonic is used for points that do not fit under any particular mechanical system for example:

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|--|----------------------------------|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| ES WTS | | | DI DI | Elevator Sump (level alarm) Weeping Tile Sump (level alarm) | MISES, MISES2 MISWTS, MISWTS2 |

4.3.31 Virtual Point Attributes

NOTE: Physical points and their mnemonics are included only to provide a context for the virtual point examples.

| MNEMONIC | | | POINT TYPE | Description | Examples |
|-----------|-------------|---------|------------|---|---|
| SYS POINT | TERM. POINT | ATTRIB. | | | |
| SAT | | GO | N/A V | Air Handling System 1 System GO flag | AH1 AH1-GO |
| | | UA | AI V | Supply Air Temperature User Adjust | AH1SAT AH1SAT-UA |
| | | SP | V | Set Point | AH1SAT-SP |
| | | CO | V | Controller | AH1SAT-CO |
| | | PG | V | Proportional Gain | AH1SAT-PG |
| | | IG | V | Integral Gain | AH1SAT-IG |
| | | DG | V | Derivative Gain | AH1SAT-DG |
| | ST* | | MAX | AI V | Space Temperatures Maximum (Space Temperature) |
| | | MIN | V | Minimum (Space Temperature) | AH1ST-MIN |
| | | AVG | V | Average (Space Temperature) | AH1ST-AVG |
| | | EFF | V | Effective (Space Temperature) | AH1ST-EFF |
| RWT | | | HL | AI V | Boiler System, Return Water Temp High Limit |
| | | LL | V | Low limit | BSRWT-LL |
| | | ALM | V | Alarm | BSRWT-ALM |
| P1 | | RT | DO V | Pump 1 Run Time | BSP1 BSP1-RT |
| | | LEAD | V | Lead/Lag Flag | BSP1-LEAD |

4.3.32 Common Virtual Points

Common mnemonics for virtual points have been described in sufficient detail previously. See article 3.0 “Virtual Points – Specifics”.

Alberta Infrastructure EMCS Standard for Logical Point Mnemonics

SAMPLE POINT SHEETS





AND


SCHEMATICS

The following point sheets and schematic diagrams are not intended to be a comprehensive compilation of all possible systems and their control points. They are only intended to be a representative sample of typical mechanical systems and the proper use of logical point mnemonics.

| Example | Mnemonic | System | Type |
|----------------|-----------------|----------------|--------------------------------------|
| 1 | AH1 | Air System | Air Handler - Constant Volume |
| 2 | MZ1 | Air System | Air Handler - Multi-Zone |
| 3 | VV1 | Air System | Air Handler - Variable Volume |
| 4 | DD1 | Air System | Air Handler - Dual Duct |
| 5 | PG | Air System | Air Handler - Parking Garage |
| 6 | AH1 | Air System | Air Handler - Roof Top Unit |
| 7 | HP | Air System | Heat Pump |
| 8 | HW | Heating System | Heating Water - Atmospheric Boilers |
| 9 | PR, TR | Heating System | Perimeter Radiation, Terminal ReHeat |
| 10 | BS | Heating System | Heating Water - Forced Draft Boilers |
| 11 | CH | Cooling System | Chilled Water, Cooling Tower |

ROOM TEMPERATURE SENSORS

-  --- AH1ST1 --- Courtroom, Main Floor
-  --- AH1ST2 --- South Offices, Main Floor
-  --- AH1ST3 --- East Offices, Main Floor
-  --- AH1ST4 --- Basement office



SYSTEM TYPE: Constant Volume

USE FOR: Constant Volume, Terminal Re-Heat, Induction

LOCATION: Penthouse Fan Room


| | | | | | | | | |
|----------------|--------|-----------|-----------|---|-----------------------|------------|-------|--------------|
| BID NO.: | B00XXX | SECTION: | 15941 | CONSULTANT NAME: | Building Name | DRAWING: | CSK-1 | |
| SITE NO.: | S00XXX | DRAWN BY: | DC | Address - Line 1 | EMCS - Air System AH1 | 01-ah1.dwg | | |
| CENTRE CODE: | XXXXX | CHK'D BY: | RU | Address - Line 2 | | | | |
| PROJ FILE NO.: | XXXXX | DATE: | 08 JAN 02 | Tel: (780) XXX-YYYY Fax: (780) XXX-YYYY | | | | |
| PLAN NO.: | 00XXXX | SCALE: | NTS | | | | | PAGE 1 of 11 |



Building Name
System: AH1 (Air Handler No.1)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|-----|------------------------------|-----------|------------|----|----|----|----|-------|-----------------------|
| 1 | Supply Fan Start/Stop | AH1 SF | Penthouse | | Ry | | | A | |
| 2 | Return Fan Start/Stop | AH1 RF | Penthouse | | Ry | | | A | |
| 3 | Exhaust Fan 1 Start/Stop | AH1 EF1 | Penthouse | | Ry | | | A | |
| 4 | Exhaust Fan 2 Start/Stop | AH1 EF2 | Penthouse | | Ry | | | A | |
| 5 | Heating Coil Pump Start/Stop | AH1 HCP | Penthouse | | Ry | | | A | |
| 6 | Humidifier Enable | AH1 H-E | Penthouse | | Ry | | | A | Packaged controller |
| 7 | Fresh/Outdoor Air Damper | AH1 FAD | Penthouse | | Ry | | | A | Minimum outdoor air |
| 8 | DX Cooling Stage 2 | AH1 DX2 | Penthouse | | Ry | | | A | |
| 9 | DX Cooling Stage 1 | AH1 DX1 | Penthouse | | Ry | | | A | |
| 10 | Supply Fan Status | AH1 SF-S | Penthouse | Ri | | | | A | Ct status relay |
| 11 | Return Fan Status | AH1 RF-S | Penthouse | Ri | | | | A | Ct status relay |
| 12 | Exhaust Fan 1 Status | AH1 EF1-S | Penthouse | Ri | | | | A | Ct status relay |
| 13 | Exhaust Fan 2 Status | AH1 EF2-S | Penthouse | Ri | | | | A | Ct status relay |
| 14 | Heating Coil Pump Status | AH1 HCP-S | Penthouse | Ri | | | | A | Ct status relay |
| 15 | Humidifier Status | AH1 H-S | Penthouse | Ri | | | | A | Packaged controller |
| 16 | Freeze Protect | AH1 FP | Penthouse | Dc | | | | A | |
| 17 | Mixed Air Temperature | AH1 MAT | Penthouse | | | Ta | | A | |
| 18 | Return Air Temperature | AH1 RAT | Penthouse | | | Tp | | A | |
| 19 | Supply Air Temperature | AH1 SAT | Penthouse | | | Tp | | A | |
| 20 | Supply Air Humidity | AH1 SAH | Penthouse | | | Hp | | A | |
| 21 | Return Air Humidity | AH1 RAH | Penthouse | | | Hp | | A | |
| 22 | Space Temperature 1 | AH1 ST1 | Main Floor | | | Tr | | A | Courtroom |
| 23 | Space Temperature 2 | AH1 ST2 | Main Floor | | | Tr | | A | South office |
| 24 | Space Temperature 3 | AH1 ST3 | Main Floor | | | Tr | | A | East office |
| 25 | Space Temperature 4 | AH1 ST4 | Basement | | | Tr | | A | Basement office |
| 26 | Mixed Air Dampers | AH1 MAD | Penthouse | | | | Da | A | |
| 27 | Heating Coil Valve | AH1 HCV | Penthouse | | | | Va | A | |
| 28 | Humidifier Setpoint Reset | AH1 H-R | Penthouse | | | | Ao | A | Packaged controller |
| | Sub-Total (This System Only) | | | 7 | 9 | 9 | 3 | | 28 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.
 - An RCU can contain the points from more than one GROUP



SYSTEM TYPE: Multi-Zone

LOCATION: Penthouse Fan Room

| | | | | | |
|----------------|--------|-----------|-----------|-----------------|-----------------------|
| BID NO.: | B00XXX | SECTION: | 15941 | CONSULTANT NAME | EMCS - Multi-Zone MZ1 |
| SITE NO.: | S00XXX | DRAWN BY: | DC | DESCRIPTION: | Building Name |
| CENTRE CODE: | XXXXX | CHK'D BY: | RU | | 02-mz1.dwg |
| PROJ FILE NO.: | XXXXX | DATE: | 09 JAN 02 | | PAGE 2 of 11 |
| PLAN NO.: | 00XXXX | SCALE: | NTS | | |

Building Name

Points Schedules - Section 15941

Page 2 of 11

System: MZ1 (Multi-Zone Air Handler No.1)








| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|--------------------------|-----------|------------|----|----|----|----|-------|-----------------------------|
| 1 | Supply Fan Start/Stop | MZ1 SF | Penthouse | | Ry | | | E | |
| 2 | Return Fan Start/Stop | MZ1 RF | Penthouse | | Ry | | | E | |
| 3 | Exhaust Fan 1 Start/Stop | MZ1 EF1 | Penthouse | | Ry | | | E | |
| 4 | Exhaust Fan 2 Start/Stop | MZ1 EF2 | Penthouse | | Ry | | | E | |
| 5 | Freeze Protect | MZ1 FP | Penthouse | Dc | | | | E | |
| 6 | Supply Fan Status | MZ1 SF-S | Penthouse | Ri | | | | E | Ct status relay |
| 7 | Return Fan Status | MZ1 RF-S | Penthouse | Ri | | | | E | Ct status relay |
| 8 | Exhaust Fan 1 Status | MZ1 EF1-S | Penthouse | Ri | | | | E | Ct status relay |
| 9 | Exhaust Fan 2 Status | MZ1 EF2-S | Penthouse | Ri | | | | E | Ct status relay |
| 10 | Mixed Air Temperature | MZ1 MAT | Penthouse | | | Ta | | E | |
| 11 | Pre-Heat Temperature | MZ1 PHT | Penthouse | | | Ta | | E | |
| 12 | Return Air Temperature | MZ1 RAT | Penthouse | | | Tp | | E | |
| 13 | Cold Deck Temperature | MZ1 CDT | Penthouse | | | Tp | | E | |
| 14 | Hot Deck Temperature | MZ1 HDT | Penthouse | | | Tp | | E | |
| 15 | Return Air Humidity | MZ1 RAH | Penthouse | | | Hp | | E | |
| 16 | Supply Air Humidity | MZ1 SAH | Penthouse | | | Hp | | E | Locate in largest zone duct |
| 17 | Mixed Air Dampers | MZ1 MAD | Penthouse | | | | Da | E | |
| 18 | Pre-Heat Coil Valve | MZ1 PCV | Penthouse | | | | Va | E | |
| 19 | Cold Deck Valve | MZ1 CDV | Penthouse | | | | Va | E | |
| 20 | Hot Deck Valve | MZ1 HDV | Penthouse | | | | Va | E | |
| 21 | Humidity Valve | MZ1 HV | Penthouse | | | | Va | E | |
| 22 | Zone 1 Space Temperature | MZ1 Z1ST | Main floor | | | Tr | | F | East office |
| 23 | Zone 2 Space Temperature | MZ1 Z2ST | Main floor | | | Tr | | F | West office |
| 24 | Zone 3 Space Temperature | MZ1 Z3ST | Main floor | | | Tr | | F | South interior zone |
| 25 | Zone 4 Space Temperature | MZ1 Z4ST | Main floor | | | Tr | | F | North office |
| 26 | Zone 5 Space Temperature | MZ1 Z5ST | Main floor | | | Tr | | F | North west office |
| 27 | Zone 1 Damper | MZ1 Z1D | Penthouse | | | | Da | F | Zone damper |
| 28 | Zone 2 Damper | MZ1 Z2D | Penthouse | | | | Da | F | Zone damper |
| 29 | Zone 3 Damper | MZ1 Z3D | Penthouse | | | | Da | F | Zone damper |
| 30 | Zone 4 Damper | MZ1 Z4D | Penthouse | | | | Da | F | Zone damper |
| 31 | Zone 5 Damper | MZ1 Z5D | Penthouse | | | | Da | F | Zone damper |
| Sub-Total (This System Only) | | | | 5 | 4 | 12 | 10 | | 31 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.


- An RCU can contain the points from more than one GROUP

18-Dec-02

SYSTEM TYPE: Variable Volume



VAV Box Control (Digital)
(zone points in TCU panel - Typ for 15 zones)



LOCATION: North Penthouse

| | | | | |
|---------------------|-----------------|--|----------------------------|--------------|
| BID NO.: B00XXX | SECTION: 15941 | Consultant Name | DESCRIPTION: | DRAWING |
| SITE NO.: S00XXX | DRAWN BY: DC | Address - Line 1 | Building Name | CSK-3 |
| CENTRE CODE: XXXXX | CHK'D BY: RU | Address - Line 2 | EMCS - Variable Volume VV1 | 03-wv1.dwg |
| PROJ FILE NO: XXXXX | DATE: 09 JAN 02 | Tel: (780) XXX-YYYY Fax: (780) XXX-YYZ | | PAGE 3 of 11 |
| PLAN NO.: 00XXXX | SCALE: NTS | | | |



Building Name

System: VV1 (Variable Volume Air Handler No.1)



| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|-----|--------------------------------|----------|--------------|----|----|----|----|-------|----------------------------|
| 1 | Supply Fan Enable | VV1 SF-E | N. Penthouse | | Ry | | | C | Speed drive |
| 2 | Return Fan Enable | VV1 RF-E | N. Penthouse | | Ry | | | C | Speed drive |
| 3 | Exhaust Fan Start/Stop | VV1 EF | N. Penthouse | | Ry | | | C | Toilet exhaust |
| 4 | Humifier Valve | VV1 HV | N. Penthouse | | Ry | | | C | Wetted media |
| 5 | Fresh/Outdoor Air Damper | VV1 FAD | N. Penthouse | | Ry | | | C | |
| 6 | Supply Fan Status | VV1 SF-S | N. Penthouse | Dc | | | | C | Dry contact in speed drive |
| 7 | Return Fan Status | VV1 RF-S | N. Penthouse | Dc | | | | C | Dry contact in speed drive |
| 8 | Exhaust Fan Status | VV1 EF-S | N. Penthouse | Ri | | | | C | Ct status relay |
| 9 | Freeze Protect | VV1 FP | N. Penthouse | Dc | | | | C | |
| 10 | Mixed Air Temperature | VV1 MAT | N. Penthouse | | | Ta | | C | |
| 11 | Supply Air Temperature | VV1 SAT | N. Penthouse | | | Tp | | C | |
| 12 | Return Air Temperature | VV1 RAT | N. Penthouse | | | Tp | | C | |
| 13 | Supply Velocity Pressure | VV1 SVP | N. Penthouse | | | Vp | | C | |
| 14 | Return Velocity Pressure | VV1 RVP | N. Penthouse | | | Vp | | C | |
| 15 | Branch Static Pressure | VV1 BSP | N. Penthouse | | | Sp | | C | |
| 16 | Return Air Humidity | VV1 RAH | N. Penthouse | | | Hp | | C | |
| 17 | Supply Air Humidity | VV1 SAH | N. Penthouse | | | Hp | | C | |
| 18 | Building Differential Pressure | VV1 BDP | N. Penthouse | | | Sp | | C | Outdoor reference |
| 19 | Mixed Air Dampers | VV1 MAD | N. Penthouse | | | | Da | C | |
| 20 | Cooling Coil Valve | VV1 CCV | N. Penthouse | | | | Va | C | |
| 21 | Return Fan Speed | VV1 RFS | N. Penthouse | | | | Ao | C | Speed drive |
| 22 | Supply Fan Speed | VV1 SFS | N. Penthouse | | | | Ao | C | Speed drive |
| | Sub-Total (This System Only) | | | 4 | 5 | 9 | 4 | | 22 points this system |

VAV BOX CONTROL POINTS (TYPICAL for 15 Zones - Refer to mechanical drawings for locations) Zone ## (01-15)


| | | | | | | | | | |
|---|----------------------------------|------------|-----------------|---|---|----|----|-------|-------------------|
| 1 | Space Temperature | VV1 B##1ST | See floor plans | | | Tr | | TCU## | |
| 2 | VAV Box Supply Velocity Pressure | VV1 B##SVP | See floor plans | | | Vp | | TCU## | |
| 3 | VAV Box Damper | VV1 B##D | See floor plans | | | | Da | TCU## | |
| 4 | ReHeat Coil Valve | VV1 B##RCV | See floor plans | | | | Va | TCU## | |
| 5 | Perimeter Radiation Valve | VV1 B##PRV | See floor plans | | | | Va | TCU## | |
| | Sub-Total (per Zone) | | | 0 | 0 | 2 | 3 | | 5 points per zone |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.
 - An RCU can contain the points from more than one GROUP

ROOM TEMP SENSORS



Exhaust Fans hardware
interlocked with Supply Fan



SYSTEM TYPE: Dual Duct

LOCATION: Fan Room No.1


| | | | | | | | |
|----------------|--------|-----------|-----------|---------------------|----------------------|---------|--------------|
| BID NO.: | B00XXX | SECTION: | 15941 | CONSULTANT NAME | EMCS - Dual Duct DD1 | DRAWING | CSK-4 |
| SITE NO.: | S00XXX | DRAWN BY: | DC | Address - Line 1 | | | |
| CENTRE CODE: | XXXXX | CHK'D BY: | RU | Address - Line 2 | | | 04-dd1.dwg |
| PROJ FILE NO.: | XXXXX | DATE: | 10 JAN 02 | Tel: (780) XXX-YYYY | | | PAGE 4 of 11 |
| PLAN NO.: | 00XXXX | SCALE: | NTS | Fax: (780) XXX-YYYY | | | |



Building Name
System: DD1 (Dual Duct Air Handler No.1)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|------------------------|-----------|---------------|----|----|----|----|-------|-------------------------------|
| 1 | Supply Fan Start/Stop | DD1 SF | Fan Room No.1 | | Ry | | | D | |
| 2 | Return Fan Start/Stop | DD1 RF | Fan Room No.1 | | Ry | | | D | |
| 3 | Return Fan Status | DD1 RF-S | Fan Room No.1 | Ri | | | | D | Ct status relay |
| 4 | Supply Fan Status | DD1 SF-S | Fan Room No.1 | Ri | | | | D | Ct status relay |
| 5 | Exhaust Fan 1 Status | DD1 EF1-S | Fan Room No.1 | Ri | | | | D | Ct status relay |
| 6 | Exhaust Fan 2 Status | DD1 EF2-S | Fan Room No.1 | Ri | | | | D | Ct status relay |
| 7 | Exhaust Fan 3 Status | DD1 EF3-S | Fan Room No.1 | Ri | | | | D | Ct status relay |
| 8 | Freeze Protect | DD1 FP | Fan Room No.1 | Dc | | | | D | Tie into hardware freeze stat |
| 9 | Mixed Air Temperature | DD1 MAT | Fan Room No.1 | | | Ta | | D | |
| 10 | Pre-Heat Temperature | DD1 PHT | Fan Room No.1 | | | Ta | | D | |
| 11 | Return Air Temperature | DD1 RAT | Fan Room No.1 | | | Tp | | D | |
| 12 | Cold Deck Temperature | DD1 CDT | Fan Room No.1 | | | Tp | | D | |
| 13 | Hot Deck Temperature | DD1 HDT | Fan Room No.1 | | | Tp | | D | |
| 14 | Return Air Humidity | DD1 RAH | Fan Room No.1 | | | Hp | | D | |
| 15 | Hot Deck Humidity | DD1 HDH | Fan Room No.1 | | | Hp | | D | Software interlock high limit |
| 16 | Mixed Air Dampers | DD1 MAD | Fan Room No.1 | | | | Da | D | |
| 17 | Pre-Heat Coil Valve | DD1 PCV | Fan Room No.1 | | | | Va | D | |
| 18 | Cold Deck Valve | DD1 CDV | Fan Room No.1 | | | | Va | D | |
| 19 | Hot Deck Valve | DD1 HDV | Fan Room No.1 | | | | Va | D | |
| 20 | Humidity Valve | DD1 HV | Fan Room No.1 | | | | Va | D | |
| 21 | Space Temperature 1 | DD1 ST1 | Main floor | | | Tr | | D | East office |
| 22 | Space Temperature 2 | DD1 ST2 | Main floor | | | Tr | | D | West office |
| 23 | Space Temperature 3 | DD1 ST3 | Main floor | | | Tr | | D | Interior zone |
| Sub-Total (This System Only) | | | | 6 | 2 | 10 | 5 | | 23 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.
 - An RCU can contain the points from more than one GROUP



SYSTEM TYPE: Parking Garage

LOCATION: Parkade

| | | | |
|-----------------------------|------------------------|--------------------------------------|---------------------|
| BID NO.: B00XXX | SECTION: 15941 | CONSULTANT NAME: | DESCRIPTION: |
| SITE NO.: S00XXX | DRAWN BY: DC | Address - Line 1 Address - Line 2 | Building Name |
| CENTRE CODE: XXXXX | CHK'D BY: RU | | |
| PROJ FILE NO.: XXXXX | DATE: 10 JAN 02 | Tel: (780) XXX-YYYY | 05-pv.dwg |
| PLAN NO.: 00XXXX | SCALE: NTS | Fax: (780) XXX-YYYY | PAGE 5 of 11 |




Building Name
System: PG (Parking Garage)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|------------------------------------|----------|------------------|----------|----------|-----------|----------|-------|----------------------------|
| 1 | Make-Up Unit Fan Low Speed | PG MUF1 | N. Penthouse | | Ry | | | C | Interlock with damper |
| 2 | Make-Up Unit Fan High Speed | PG MUFH | N. Penthouse | | Ry | | | C | |
| 3 | Exhaust Fan 1 Low Speed | PG EFL1 | N. Penthouse | | Ry | | | C | Parkade exhaust |
| 4 | Exhaust Fan 1 High Speed | PG EFH1 | N. Penthouse | | Ry | | | C | |
| 5 | Exhaust Fan 2 Low Speed | PG EFL2 | N. Penthouse | | Ry | | | C | Parkade exhaust |
| 6 | Exhaust Fan 2 High Speed | PG EFH2 | N. Penthouse | | Ry | | | C | |
| 7 | Exhaust Fan 1 Status | PG EF1-A | N. Penthouse | | | Ct | | C | Motor current |
| 8 | Exhaust Fan 2 Status | PG EF2-A | N. Penthouse | | | Ct | | C | Motor current |
| 9 | Make-Up Unit Fan Amps | PG MUF-A | N. Penthouse | | | Ct | | C | Motor current |
| 10 | Make-Up Unit Supply Air Temp. | PG MUSAT | N. Penthouse | | | Tp | | C | |
| 11 | Differential Pressure | PG DP | N. Penthouse | | | Sp | | C | Reference parkade to lobby |
| 12 | Make-Up Unit Supply SetPoint Reset | PG MU-R | N. Penthouse | | | | Ao | C | Packaged controls |
| 13 | CO2 Sensor No.1 | PG C01 | Parkade Level P1 | | | CO | | C | Refer to floor plan |
| 14 | CO2 Sensor No.2 | PG C02 | Parkade Level P1 | | | CO | | C | Refer to floor plan |
| 15 | CO2 Sensor No.3 | PG C03 | Parkade Level P1 | | | CO | | C | Refer to floor plan |
| 16 | CO2 Sensor No.4 | PG C04 | Parkade Level P2 | | | CO | | C | Refer to floor plan |
| 17 | CO2 Sensor No.5 | PG C05 | Parkade Level P2 | | | CO | | C | Refer to floor plan |
| 18 | CO2 Sensor No.6 | PG C06 | Parkade Level P2 | | | CO | | C | Refer to floor plan |
| 19 | CO2 Sensor No.7 | PG C07 | Parkade Level P3 | | | CO | | C | Refer to floor plan |
| 20 | CO2 Sensor No.8 | PG C08 | Parkade Level P3 | | | CO | | C | Refer to floor plan |
| 21 | CO2 Sensor No.9 | PG C09 | Parkade Level P3 | | | CO | | C | Refer to floor plan |
| 22 | Space Temperature | PG ST | Parkade Level P1 | | | Tr | | C | Locate near vehicle door |
| Sub-Total (This System Only) | | | | 0 | 6 | 15 | 1 | | 22 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP



SYSTEM TYPE: Roof Top Unit

| | | | | | |
|----------------|--------|-----------|-----------|--|--------------|
| BID NO.: | B00XXX | SECTION: | 15941 | CONSULTANT NAME: | DRAWING: |
| SITE NO.: | S00XXX | DRAWN BY: | DC | Building Name EMCS - Roof Top Unit (Packaged Controls) | CSK-6 |
| CENTRE CODE: | XXXXX | CHK'D BY: | RU | | 06-rtu.dwg |
| PROJ FILE NO.: | XXXXX | DATE: | 10 JAN 02 | Tel: (780) XXX-YYY | PAGE 6 of 11 |
| PLAN NO.: | 00XXXX | SCALE: | NTS | Fax: (780) XXX-YYY | |



Building Name

Points Schedules - Section 15941

Page 6 of 11


System: AH1 (Roof Top Unit with Packaged Controls)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|--------------------------------|-----------|----------|----|----|----|----|-------|--------------------------------|
| 1 | RTU 1 Enable | AH1 -E | Roof | | Ry | | | B | Connect to packaged controls |
| 2 | RTU Mix Dampers Econo Override | AH1 MAD-O | Roof | | Ry | | | B | Connect to packaged controls |
| 3 | RTU DX Cooling Stage 1 | AH1 DX1 | Roof | | Ry | | | B | Packaged controls (DX cooling) |
| 4 | RTU DX Cooling Stage 2 | AH1 DX2 | Roof | | Ry | | | B | Packaged controls (DX cooling) |
| 5 | RTU 1 Fan Status | AH1 SF-S | Roof | Ri | | | | B | Provide CT status relay on fan |
| 6 | RTU 1 Fault | AH1 -F | Roof | Dc | | | | B | Unit alarm contact |
| 7 | Supply Air Temperature | AH1 SAT | Ceiling | | | Tp | | B | Locate in ceiling ductwork |
| 8 | Return Air Temperature | AH1 RAT | Ceiling | | | Tp | | B | Locate in ceiling ductwork |
| 9 | Space Temperature | AH1 ST | Room 205 | | | Tr | | B | See floor plan for location |
| 10 | RTU Supply Air SetPoint Reset | AH1 -R | Roof | | | | Ao | B | Connect to packaged controls |
| Sub-Total (This System Only) | | | | 2 | 4 | 3 | 1 | | 10 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP

18-Dec-02



SYSTEM TYPE: Heat Pump

| | | | |
|--------------------|-----------------|--|--|
| BID NO.: B00XXX | SECTION: 15941 | Alberta INFRASTRUCTURE | Consultant Name Address - Line 1 Address - Line 2 Tel: (780) XXX-YYY Fax: (780) XXX-YYZ |
| SITE NO.: S00XXX | DRAWN BY: DC | DESCRIPTION: Building Name EMCS - Heat Pump Loop | |
| CENTRE CODE: XXXX | CHK'D BY: RU | | |
| PROJ FILE NO: XXXX | DATE: 13 JAN 02 | DRAWING CSK-7 07-hp.dwg PAGE 7 of 11 | |
| PLAN NO.: 00XXXX | SCALE: NTS | | |

Building Name

Points Schedules - Section 15941

System: HP (Water Source Heat Pump)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|-----|---------------------------------|---------|-----------|----|----|----|----|-------|----------------------------|
| 1 | Loop Pump 1 Start/Stop | HP LP1 | Penthouse | | Ry | | | M | Lead/Lag with P1 |
| 2 | Loop Pump 2 Start/Stop | HP LP2 | Penthouse | | Ry | | | M | Lead/Lag with P2 |
| 3 | Loop Heat Injection Valve | HP LHIV | Penthouse | | Ry | | | M | Two position valve |
| 4 | Loop Pump 1 Status | HP P1-S | Penthouse | Ri | | | | M | Ct status relay |
| 5 | Loop Pump 2 Status | HP P2-S | Penthouse | Ri | | | | M | Ct status relay |
| 6 | Loop Supply Temperature | HP LST | Penthouse | | | Tw | | M | |
| 7 | Loop Return Temperature | HP LRT | Penthouse | | | Tw | | M | |
| 8 | Heat Exchanger Valve | HP HEV | Penthouse | | | | Ao | M | |
| 9 | Cooling Tower Pump Start/Stop | CT P | Penthouse | | Ry | | | M | |
| 10 | Cooling Tower Fan Enable | CT F-E | Penthouse | | Ry | | | M | Speed drive |
| 11 | Cooling Tower Pump Status | CT P-S | Penthouse | Ri | | | | M | |
| 12 | Cooling Tower Fan Status | CT F-S | Penthouse | Dc | | | | M | Dry contact in speed drive |
| 13 | Cooling Tower Supply Water Temp | CT SWT | Penthouse | | | Tw | | M | |
| 14 | Cooling Tower Fan Speed | CT FS | Penthouse | | | | Ao | M | Speed drive |
| | Sub-Total (This System Only) | | | 4 | 5 | 3 | 2 | | 14 points this system |



HEAT PUMP UNIT CONTROL POINTS (TYPICAL for 15 Zones - Refer to mechanical drawings for locations) Zone ## (01-15)

| | | | | | | | | | |
|---|------------------------------|-----------|---------------|----|----|----|---|-------|-------------------------------|
| 1 | Unit 1 Compressor Enable | HP U##C-E | Ceiling space | | Ry | | | TCU## | Compressor lock-out |
| 2 | Unit 1 Fan Start/Stop | HP U##F | Ceiling space | | Ry | | | TCU## | |
| 3 | Unit 1 Reversing Valve | HP U##RV | Ceiling space | | Ry | | | TCU## | Heat/Cool mode |
| 4 | Unit 1 Occupancy Override | HP U##O | Room 101 | Mc | | | | TCU## | Momentary contact push button |
| 5 | Unit 1 Fan Status | HP U##F-S | Ceiling space | Ri | | | | TCU## | Ct status relay |
| 6 | Unit 1 Space Temperature | HP U##ST | Room 101 | | | Tr | | TCU## | |
| | Sub-Total (This System Only) | | | 2 | 3 | 1 | 0 | | 6 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP

18-Dec-02



SYSTEM TYPE: Heating Water Atmospheric Boilers (Natural Draft)

| | | | | | |
|------------------------|-----------------|--|--|-----------------------|--|
| SECTION: 15941 | | CONSULTANT NAME | | LOCATION: Boiler Room | |
| BID NO.: B00XXX | DRAWN BY: DC | Building Name | | DRAWING | |
| SITE NO.: S00XXX | CHK'D BY: RU | | | CSK-8 | |
| CENTRE CODE: XXXXX | DATE: 11 JAN 02 | EMCS - Heating Water Atmospheric Boilers | | 08-hw-a.dwg | |
| PROJ FILE NO: XXXXX | SCALE: NTS | | | PAGE 8 of 11 | |
| PLAN NO.: 00XXXX | | Tel: (780) XXX-YYYY Fax: (780) XXX-YYYY | | | |
| Alberta INFRASTRUCTURE | | Address - Line 1 | | | |
| | | Address - Line 2 | | | |

Building Name

Points Schedules - Section 15941

Page 8 of 11



System: HW (Hot Water Heating System - Atmospheric Boilers)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|---------------------------|---------|----------------|----|----|----|----|-------|-----------------------|
| 1 | Boiler 1 Low Fire | HW B1LF | Boiler Rm. | | Ry | | | A | 2 stage burner |
| 2 | Boiler 1 High Fire | HW B1HF | Boiler Rm. | | Ry | | | A | 2 stage burner |
| 3 | Boiler 2 Low Fire | HW B2LF | Boiler Rm. | | Ry | | | A | 2 stage burner |
| 4 | Boiler 2 High Fire | HW B2HF | Boiler Rm. | | Ry | | | A | 2 stage burner |
| 5 | Heating Pump 1 Start/Stop | HW P1 | Boiler Rm. | | Ry | | | A | |
| 6 | Heating Pump 1 Status | HW P1-S | Boiler Rm. | Ri | | | | A | Ct status relay |
| 7 | Heating Pump 2 Start/Stop | HW P2 | Boiler Rm. | | Ry | | | A | |
| 8 | Heating Pump 2 Status | HW P2-S | Boiler Rm. | Ri | | | | A | Ct status relay |
| 9 | Return Water Temperature | HW RWT | Boiler Rm. | | | | Tw | A | |
| 10 | Supply Water Temperature | HW SWT | Boiler Rm. | | | | Tw | A | |
| 11 | Outside Air Temperature | OAT | North Exposure | | | | To | A | Note 4: Sun Shield |
| Sub-Total (This System Only) | | | | 2 | 6 | 3 | 0 | | 11 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP

18-Dec-02



LOCATION: Boiler Room

| | | | | |
|---------------------|-----------------|---------------------|----------------------|--------------|
| BID NO.: B00XXX | SECTION: 15941 | CONSULTANT NAME | DESCRIPTION: | DRAWING |
| SITE NO.: S00XXX | DRAWN BY: DC | Address - Line 1 | Building Name | CSK-9 |
| CENTRE CODE: XXXXX | CHK'D BY: RU | Address - Line 2 | EMCS - Heating Water | 9-hss.dwg |
| PROJ FILE NO: XXXXX | DATE: 11 JAN 02 | Tel: (780) XXX-YYYY | Secondary Systems | PAGE 9 of 11 |
| PLAN NO.: 00XXXX | SCALE: NTS | Fax: (780) XXX-YYYY | | |

Building Name

Points Schedules - Section 15941

Page 9a of 11

System: PR (Perimeter Radiation)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|--------------------------|---------|------------|----|----|----|----|-------|--------------------------------|
| 1 | Pump 1 Enable | PR P1-E | Boiler Rm. | | Ry | | | A | Speed drive |
| 2 | Pump 1 Status | PR P1-S | Boiler Rm. | Dc | | | | A | Dry contact in speed drive |
| 3 | Pump 1 Speed | PR P1S | Boiler Rm. | | | | Ao | A | Speed drive |
| 4 | Pump 2 Enable | PR P2-E | Boiler Rm. | | Ry | | | A | Speed drive |
| 5 | Pump 2 Status | PR P2-S | Boiler Rm. | Dc | | | | A | Dry contact in speed drive |
| 6 | Pump 2 Speed | PR P1S | Boiler Rm. | | | | Ao | A | Speed drive |
| 7 | Supply Water Temperature | PR SWT | Boiler Rm. | | | Tw | | A | |
| 8 | Return Water Temperature | PR RWT | Boiler Rm. | | | Tw | | A | |
| 9 | Differential Pressure | PR DP | Boiler Rm. | | | Dp | | A | Vary pump speed to maintain DP |
| 10 | Control Valve | PR V | Boiler Rm. | | | | Va | A | |
| Sub-Total (This System Only) | | | | 2 | 2 | 3 | 3 | | 10 points this system |

Building Name

Points Schedules - Section 15941




Page 9b of 11

System: TR (Terminal ReHeat)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|--------------------------|---------|------------|----|----|----|----|-------|----------------------|
| 1 | Pump 1 Start/Stop | TR P1 | Boiler Rm. | | Ry | | | B | |
| 2 | Pump 1 Status | TR P1-S | Boiler Rm. | Ri | | | | B | Ct status relay |
| 3 | Pump 2 Start/Stop | TR P2 | Boiler Rm. | | Ry | | | B | |
| 4 | Pump 2 Status | TR P2-S | Boiler Rm. | Ri | | | | B | Ct status relay |
| 5 | Supply Water Temperature | TR SWT | Boiler Rm. | | | Tw | | B | |
| 6 | Return Water Temperature | TR RWT | Boiler Rm. | | | Tw | | B | |
| 7 | Control Valve | TR V | Boiler Rm. | | | | Va | B | |
| Sub-Total (This System Only) | | | | 2 | 2 | 2 | 1 | | 7 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.
 - An RCU can contain the points from more than one GROUP

18-Dec-02



SYSTEM TYPE: Boilers (forced draft)

| | | |
|---|-----------------|----------------------|
| LOCATION: Boiler Room | | |
| | DESCRIPTION: | DRAWING |
| | | Building Name |
| | | EMCS - Heating Water |
| | | Forced Draft Boilers |
| CONSULTANT NAME | | DRAWING |
| Address - Line 1 | | CSK-10 |
| Address - Line 2 | | 10-hw-fd.dwg |
| Tel: (780) XXX-YYYY Fax: (780) XXX-YYYY | | PAGE 10 of 11 |
| | SECTION: 15941 | SCALE: NTS |
| BID NO.: B00XXX | DRAWN BY: DC | |
| SITE NO.: S00XXX | CHK'D BY: RU | |
| CENTRE CODE: XXXXX | DATE: 11 JAN 01 | |
| PROJ FILE NO: XXXXX | | |
| PLAN NO.: 00XXXX | | |

Building Name

Points Schedules - Section 15941

Page 10 of 11


System: BS (Boiler System)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|------------------------------|-----------------------------|---------|----------------|----|----|----|----|-------|------------------------------|
| 1 | Boiler 1 Enable | BS B1-E | Boiler Rm. | | Ry | | | A | |
| 2 | Boiler 1 Flame Failure | BS B1FF | Boiler Rm. | Dc | | | | A | Wire to common alarm contact |
| 3 | Boiler 1 Gas Valve | BS B1GV | Boiler Rm. | | | | Ao | A | |
| 4 | Boiler 1 Supply Temperature | BS B1ST | Boiler Rm. | | | Tw | | A | |
| 5 | Boiler 2 Enable | BS B2-E | Boiler Rm. | | Ry | | | A | |
| 6 | Boiler 2 Flame Failure | BS B2FF | Boiler Rm. | Dc | | | | A | Wire to common alarm contact |
| 7 | Boiler 2 Gas Valve | BS B2GV | Boiler Rm. | | | | Ao | A | |
| 8 | Boiler 2 Supply Temperature | BS B2ST | Boiler Rm. | | | Tw | | A | |
| 9 | Differential Pressure | BS DP | Boiler Rm. | | | Dp | | A | |
| 10 | Pressure By-Pass Valve | BS PBV | Boiler Rm. | | | | Va | A | Head Pressure Bypass |
| 11 | Pump 1 Start/Stop | BS P1 | Boiler Rm. | | Ry | | | A | |
| 12 | Pump 1 Status | BS P1-S | Boiler Rm. | Ri | | | | A | Ct status relay |
| 13 | Pump 2 Start/Stop | BS P2 | Boiler Rm. | | Ry | | | A | |
| 14 | Pump 2 Status | BS P2-S | Boiler Rm. | Ri | | | | A | Ct status relay |
| 15 | Supply Water Temperature | BS SWT | Boiler Rm. | | | Tw | | A | |
| 16 | Return Water Temperature | BS RWT | Boiler Rm. | | | Tw | | A | |
| 17 | Outside Air Temperature | OAT | North Exposure | | | To | | A | Note 4: (Sun Shield) |
| Sub-Total (This System Only) | | | | 4 | 4 | 6 | 3 | | 17 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP

18-Dec-02



SYSTEM TYPE:
Chilled Water
and
Cooling Tower

LOCATION: South Penthouse

| | | | | | | |
|--|---|---|---|---|--|---|
| BID NO.: B00XXX SITE NO.: S00XXX CENTRE CODE: XXXXX PROJ FILE NO: XXXXX PLAN NO.: 00XXXX | SECTION: 15941 DRAWN BY: DC CHK'D BY: RU DATE: 11 JAN 02 SCALE: NTS | Alberta <small>INFRASTRUCTURE</small> | Consultant Name Address - Line 1 Address - Line 2 Tel: (780) XXX-YYYY Fax: (780) XXX-YYYY | | DESCRIPTION: Building Name EMCS: Chilled Water - CW Cooling Tower - CT | DRAWING CSK-11 11-cw.dwg PAGE 11 of 11 |
| | Tel: (780) XXX-YYYY Fax: (780) XXX-YYYY | | | Building Name EMCS: Chilled Water - CW Cooling Tower - CT | | DRAWING CSK-11 11-cw.dwg PAGE 11 of 11 |

Building Name
System: CW (Chilled Water & Cooling Tower)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|-----|------------------------------|---------|-----------------|----|----|----|----|-------|-------------------------------|
| 1 | Chiller Enable | CW C-E | South Penthouse | | Ry | | | F | |
| 2 | Chiller Status | CW C-S | South Penthouse | Dc | | | | F | From chiller controls package |
| 3 | Chiller Fault | CW C-F | South Penthouse | Dc | | | | F | From chiller controls package |
| 4 | Chiller Current Draw (Amps) | CW C-A | South Penthouse | | | Ct | | F | |
| 5 | Chiller SWT Setpoint Reset | CW C-R | South Penthouse | | | | Ao | F | |
| 6 | Pump 1 Start/Stop | CW P1 | South Penthouse | | Ry | | | F | |
| 7 | Pump 1 Status | CW P1-S | South Penthouse | Ri | | | | F | Ct status relay |
| 8 | Expansion Tank | CW ET | South Penthouse | Dc | | | | F | Provide level switch |
| 9 | Return Water Temp | CW RWT | South Penthouse | | | Tw | | F | |
| 10 | Supply Water Temp | CW SWT | South Penthouse | | | Tw | | F | |
| | Sub-Total (This System Only) | | | 4 | 2 | 3 | 1 | | 10 points this system |

Building Name
System: CT (Cooling Tower)

| No. | Description | Label | Location | DI | DO | AI | AO | Group | Remarks / Notes |
|-----|------------------------------|--------|-----------------|----|----|----|----|-------|-----------------------|
| 1 | Fan Start/Stop | CT F | South Penthouse | | Ry | | | F | |
| 2 | Fan Status | CT F-S | South Penthouse | Ri | | | | F | Ct status relay |
| 3 | Dump Valves | CT D | South Penthouse | | Ry | | | F | |
| 4 | Heat Trace | CT HT | South Penthouse | | Ry | | | F | Cycle based on OAT |
| 5 | Sump Heater | CT SH | South Penthouse | | Ry | | | F | Electric |
| 6 | Pump Start/Stop | CT P | South Penthouse | | Ry | | | F | |
| 7 | Pump Status | CT P-S | South Penthouse | Ri | | | | F | Ct status relay |
| 8 | Basin Temperature | CT BT | South Penthouse | | | Tw | | F | |
| 9 | Supply Water Temperature | CT SWT | South Penthouse | | | Tw | | F | |
| 10 | Return Water Temperature | CT RWT | South Penthouse | | | Tw | | F | |
| | Sub-Total (This System Only) | | | 2 | 5 | 3 | 0 | | 10 points this system |

NOTE: - Points with the same GROUP designation must be located together in the same RCU.

- An RCU can contain the points from more than one GROUP