

**Addendum No. 001, February 23, 2023**

| Housing Project Name | Municipal Address       | Contract Ref. Number |
|----------------------|-------------------------|----------------------|
| Sample Lodge         | 123 123 Street, Alberta | XXX-2020-001-A       |
| Sample Lodge         | 123 123 Street, Alberta |                      |

TO: **ALL BIDDERS**

This addendum forms part of the Bid/Contract Package documents and modifies them as follows:

**MODIFICATION TO BID CLOSING DATE**

***The Bid Closing Date is extended to February 23, 2023. Time and bid submission method remain as specified.***

**MODIFICATIONS TO PREVIOUSLY ISSUED ADDENDUM NO. 001, February 23, 2023.**

1. **Addendum No. [ ], dated [Insert Date of Addendum]**

.1 Refer to Item 1.1

**DELETE:** paragraph in its entirety.

**ADD:** Edges to be tongue and groove (T&G).

**REVISE:** to read as follows.

“Canadian Softwood Plywood: to CSA O151, tongue and groove (T&G) edges.”

**BID/CONTRACT PACKAGE**

1. **Schedule B – Description of Work**

.1 Refer to paragraph 2.2.1

**DELETE:** paragraph in its entirety.

**ADD:** Edges to be tongue and groove (T&G).

**REVISE:** to read as follows.

“Canadian Softwood Plywood: to CSA O151, tongue and groove (T&G) edges.”

**SPECIFICATIONS**

1. **Section 06 10 00 – Rough Carpentry**

.1 Refer to paragraph 2.2.1

**DELETE:** paragraph in its entirety.

**ADD:** Edges to be tongue and groove (T&G).

**REVISE:** to read as follows.

“Canadian Softwood Plywood: to CSA O151, tongue and groove (T&G) edges.”

**DRAWINGS**

1. **Architectural Drawing – 101, Floor Plan, Wall Section & Details**

.1 Refer to Detail 3/101

**DELETE:** detail in its entirety.

**ADD:** note that reads “Install resilient channels on conference room side of partition.”

**Addendum No. 001, February 23, 2023**

**REVISE:** as follows.

“Sound attenuating batt insulation to be 63 mm thickness.”

**CLARIFICATION:** Partition is to run up to underside of decking above but the sound attenuating batt insulation is only installed to 300 mm above the finish ceiling. Refer to ASK-1, attached.”

**ATTACHMENTS**

The following are attached hereto and form part of this addendum:

1. ASK-1 – Clarification Sketch
2. Hazmat Report

**END OF ADDENDUM**