

- BY-PASS FILTER, AND SAMPLE COOLER MUST BE LOCATED AT OPERATOR LEVEL AWAY FROM ANY ELECTRICAL EQUIPMENT
- ENSURE DRAIN VALVES ARE INSTALLED IN ALL SYSTEM LOW POINTS

Installation of Chemical Pot Feeder, By-Pass Filter,
Corrosion Coupon Rack, & Sample Cooler