



- NOTE: 1. STEEL LADDER RUNGS TO BE INSTALLED AT 40cm ± INTERVALS IN BOXES HAVING A DEPTH OF MORE THAN 1m  
e.g. BOXES OF DEPTH 1m TO 1.5 m TO HAVE ONE 19 mm STEEL RUNG 40 cm FROM BOTTOM.
2. DRAIN PIPES TO BE EITHER REINFORCED CONCRETE PIPE OR CORRUGATED STEEL PIPE AS SPECIFIED.
3. PIPE OR PIPES TO BE INSTALLED IN ANY WALL OR WALLS AS REQUIRED.
4. TOP OF INLET TO BE FLUSH WITH TOP OF FINISHED PAVEMENT PROVISION SHALL BE MADE IN CONSTRUCTION OF INLET TO ACCOMMODATE SURFACE DRAINAGE WHEN HIGHWAY CONSTRUCTION IS IN STAGES.
5. STANDARD STRUCTURE SHOWN. NOMINAL METRIC DIMENSIONS.

	DWG No	CB 6 2.10 M10
		Date
	Original	May, 1979
	Revised	Dec., 1986

**CONCRETE  
STORM DRAIN INLET  
900 mm x 1200 mm OPENING**