



**NOTES:**

1. MAXIMUM PIPE PROJECTION INTO MANHOLE - 150mm.
2. LADDER RUNGS TO BE INSTALLED 400mm FROM BOTTOM AND AT 400mm INTERVALS.
3. MANHOLE SHALL CONFORM TO A.S.T.M. SPEC C-478.
4. NOMINAL METRIC DIMENSIONS SHOWN.
5. MANHOLES WHICH EXCEED THE STANDARD DEPTH WILL BE MEASURED BY THE UNIT OF STANDARD DEPTH PLUS THE VERTICAL LENGTH IN EXCESS OF THE STANDARD DEPTH IN LINEAR METRES. MANHOLES OF LESS THAN STANDARD DEPTH WILL BE MEASURED AND PAID FOR AS A STANDARD DEPTH UNIT.
6. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.

△			
△	Dimension and "T" top revised	B.K.	06/94
No.	REVISIONS	BY	DATE

Approved:  Executive Director, Roadway Engineering Branch	
Date: MARCH 8, 1990	

**PRECAST REINFORCED  
CATCH BASIN MANHOLE  
(1050 mm DIAMETER)**

Prepared By: LT	Checked By: B.K.	Scale: N.T.S.	Dwg No.: CB6-2.10 M30
-----------------	------------------	---------------	-----------------------