



NOTE:

1. ALL BACKFILL SHALL BE PLACED IN LAYERS NOT EXCEEDING 150 mm IN DEPTH AND EACH LAYER THOROUGHLY COMPACTED AT OPTIMUM MOISTURE CONTENT.
2. RIP-RAP OF TYPE AS SPECIFIED TO BE PLACED AT CULVERT ENDS.
3. BEDDING TO BE SHAPED TO CONFORM TO BELL JOINTS.

Alberta
TRANSPORTATION
Engineering Division

DWG. No	CB - 6 2.4.M15
	Date
Original	May, 1979
Revised	
Revised	

**TYPICAL
REINFORCED CONCRETE PIPE
INSTALLATION**