



- * CONDUIT TO BE 75mm P.V.C. TYPE DB2 (2.67mm MINIMUM WALL THICKNESS).
- * FISH WIRE TO BE 3.66mm SOFT GALVANIZED WIRE.
- * CONDUIT LOCATING PINS TO BE 450mm x 12mm BENT DEFORMED BARS OR 300mm x 10mm SPIKES AS SUPPLIED.
- * AT THE UPPER CONDUIT TERMINATOR, THE BURIAL DEPTH BELOW FINISHED GRADE (DIMENSION A), SHALL BE 850mm (± 100 mm) TO THE TOP OF THE CONDUIT.
- * CONDUIT INVERTS WILL BE AS DIRECTED BY THE ENGINEER.
- * DEPTH OF COVER AT THE LOWER CONDUIT TERMINATOR SHALL BE 1180mm (± 100 mm).

	DWG. NO. CB-6 2.7M2
	DATE: DEC. 1984
	REVISED

TYPICAL ELECTRICAL CONDUIT INSTALLATION